

**ANNUAL DUST CONTROL REPORT
PACIFICORP / Dave Johnston Plant**

From: 10/01/2016

To: 9/30/2017

Introduction:

PacifiCorp / Dave Johnston Plant has prepared this Annual Dust Control Report in accordance with 40 CFR 257.80(c) to document the following information for the PacifiCorp / Dave Johnston Plant:

- Description of the actions taken to control CCR fugitive dust
- Summary of any concerns raised by stakeholders
- Description of any corrective actions taken

Description of actions taken:

During the last 12 months, dust control procedures have been implemented at Dave Johnston Plant as discussed in the Dust Control Plan, dated October 05, 2015. A copy of the current Dust Control Plan is available in the Facility operating record and on the PacifiCorp internet site, as required by 40 CFR 257.105(g) and 257.107(g).

Record of citizen complaints:

During the last 12 months, the following concerns or complaints have been received by Dave Johnston Plant:

Date	CCR Unit	What Happened?	Corrective Actions
NONE			

Daily gallons of water applied:

CCR Unit	# Days Watered	Gallons of Water Applied	Notes
4A Pond 4B Pond	11	77,000	Split between the ponds as needed
Expansion Landfill	96	1,684,000	Extra watering apart from the haul road gallons.
Haul Roads	187	5,347,500	Note: When watering the haul roads the Expansion Landfill is automatically watered as the dumping area is included in the haul road route.

Summary of chemical suppressant, type, quantity, location, and date:

Date	CCR Unit	Chemical	Tons
6/30/2017	Haul Roads & Expansion Landfill	Magnesium Chloride	34 tons mixed with water
7/10/2017	Haul Roads & Expansion Landfill	Magnesium Chloride	34 tons mixed with water
9/24/2017	Haul Roads & Expansion Landfill	Magnesium Chloride	34 tons mixed with water

Additional CCR fugitive dust Best Practices: (e.g. wind breaks, synthetic covers, vegetative covers. Etc)

Date	CCR Unit	Best Practice Applied
NONE		

Curtailement Events Summary:

Date	CCR Unit	What Happened?	Corrective Actions
NONE			

Extraordinary Events Summary:

Date	CCR Unit	What Happened?	Corrective Actions
NONE			

Closing:

A copy of the most recent Annual Dust Control Report is available in the Facility operating record and on the PacifiCorp CCR internet site, as required by 40 CFR 257.105(g) and 257.107(g).