



Hunter Plant

2 Miles South of Castle Dale on Highway 10
P.O. Box 569
Castle Dale, UT 84513

September 4, 2020

Ty L Howard, Director
Utah Department of Environmental Quality
Division of Waste Management and Radiation Control
P.O. Box 144880
Salt Lake City, UT 84114-4880

**Subject: Hunter CCR Landfill Semiannual Assessment Monitoring Second Half 2019
Appendix IV Ground Water Protection Standard Notification**

Dear Mr. Howard,

This updated notification is to correct the notification sent on August 31, 2020 that incorrectly referencing the first half 2019 rather than the second half 2019 in the Subject line.

In accordance with 40 CFR 257.95(g) the results of ground water assessment monitoring indicate that a notification is required for the coal combustion residual unit CCR Landfill at the Hunter Power Plant in Castle Dale, Utah. PacifiCorp has completed the 2019 second half subsequent assessment monitoring and the statistical analysis resulting in the following results. The results were also submitted in the 2019 Groundwater Monitoring and Corrective Action Report.

Sampling Event	Appendix IV Constituents Exceeding Groundwater Protection Standards
2018 Assessment Monitoring	Lithium and Molybdenum
First Half 2019 Assessment Monitoring	Cobalt, Lithium, and Molybdenum
Second Half 2019 Assessment Monitoring	Cobalt, Lithium, Molybdenum and Selenium

PacifiCorp is currently process of selecting a remedy as required in 40 CFR 257.97(a)(1).

If you have any questions regarding the notification please contact Tyson Ekker Environmental Engineer 435.748.6274.

Sincerely,

Laren Huntsman
Managing Director, Hunter Power Plant

cc
Steve Jensen NTO 210