PACIFICORP
A BERKSHIRE HATHAWAY ENERGY COMPANY

Huntington Power Plant
8 miles west of Huntington on Hwy. 31
P.O. Box 680
Huntington, Utah 84528

March 7, 2018

Scott T. Anderson, Director
Utah Department of Environmental Quality
Division of Waste Management and Radiation Control
P.O. Box 144880
Salt Lake City, UT 84114-4880

Subject: Huntington CCR Landfill Assessment Monitoring Program Notification

Dear Mr. Anderson,

In accordance with 40 CFR 257.94(e)(3) and R307-319(e)(3) an assessment monitoring program has been established for the coal combustion residual unit CCR Landfill at the Huntington Power Plant in Huntington, Utah. As reflected in the Groundwater Monitoring and Corrective Action Report dated January 31, 2018, the CCR Landfill will begin assessment monitoring according to the requirements of 40 CFR 257.95 and R307-319-95, which includes the following:

- Conduct the first assessment monitoring sampling event for Appendix IV constituents
- Complete background comparisons for Appendix IV constituents
- Conduct a second assessment monitoring event within 90-days of the first, and analyze the samples for all Appendix II constituents and those Appendix IV constituents exceeding background if any
- Update the site-specific statistical analysis incorporating the new data
- Establish groundwater protection standards for Appendix III and Appendix IV constituent, as necessary
- Develop an Assessment Monitoring Report detailing the findings of the phase

A complete discussion of the monitoring network used in the assessment monitoring is provided in the Sampling and Analysis Plan, CCR Landfill Huntington Power Plant in Huntington, Utah, 2017, which is part of the facility operating record.

If you have any questions regarding the notification please contact Russ Willson Environmental Analyst 435.687.4331.

Sincerely,

Darrell Cunningham
Managing Director, Huntington Power Plant

Enclosures: 2018 Annual CCR Groundwater Monitoring and Corrective Action Report
cc
Steve Jensen NTO 210