PACIFICORP
A BERKSHIRE HATHAWAY ENERGY COMPANY

**Huntington Power Plant**
*8 miles west of Huntington on Hwy. 31*
*P.O. Box 680*
*Huntington, Utah 84528*

November 10, 2020

Ty L Howard, Director
Utah Department of Environmental Quality
Division of Waste Management and Radiation Control
P.O. Box 144880
Salt Lake City, UT 84114-4880

**Subject: Huntington CCR Landfill Semiannual Assessment Monitoring First Half 2020**
**Appendix IV Ground Water Protection Standard Notification**

Dear Mr. Howard,

In accordance with 40 CFR 257.95(g) the results of ground water assessment monitoring indicate that a notification is required for the coal combustion residual unit CCR Landfill at the Huntington Power Plant in Huntington, Utah. PacifiCorp has completed the 2020 first half subsequent assessment monitoring and the statistical analysis resulting in the following results.

| Sampling Event | Appendix IV Constituents Exceeding Groundwater Protection Standards |
|---|---|
| 2018 Assessment Monitoring | Chromium, Cobalt, Lithium, Molybdenum, and Selenium |
| First Half 2019 Assessment Monitoring | Cobalt, Lithium, and Selenium |
| Second Half 2019 Assessment Monitoring | Fluoride, Lithium, and Selenium |
| First Half 2020 Assessment Monitoring | Lithium and Selenium |

If you have any questions regarding the notification please contact Russ Willson Environmental Analyst 435.687.4331.

Sincerely,

Darrell Cunningham
Managing Director, Huntington Power Plant

cc
Steve Jensen NTO 210