## Pendleton Area Distribution System Planning Community Workshop #1 April 8<sup>th</sup>, 2024

Presenters:

Ian Hoogendam – DSP Manager, Daniel Talbot– Engineer, Ryan Harvey – CBRE Product Manager







## **Microsoft Teams meeting info:**

Join on your computer, mobile app or room device <u>Click here to join the meeting</u> Meeting ID: 250 445 903 478 Passcode: Zbe8wy <u>Download Teams</u> | Join on the web <u>Call in (audio only)</u> +1 563-275-5003,,579002561# United States, Davenport Phone Conference ID: 579 002 561#

Phone Conference ID: 579 002 561#

- Please place your phone on "Mute" when not speaking
- If you call in using your phone in addition to joining via the online link, please make sure to mute your computer audio
- Please **do not use the "Hold"** function on your phone

#### **Participation:**

This workshop is available to the public, and there is a Questions/Comment section at the end of the workshop for online participants.

Please input your name and organization into the chat when you enter, and please "raise your hand" during the Open Discussion section to ask questions or provide input.

This workshop will be recorded and published to the PacifiCorp DSP website.

## Today's Agenda

5	Introductions	
15	Utility and Distribution System Planning Overview	
10	Community Based Renewable Energy Pilot	
15	Break	
15	Study Area Overview	
15	Forecasting/Preliminary Grid Needs	
15	Open Discussion	

### **DISTRIBUTION SYSTEM PLANNING**

## Introductions – Pacific Power Team Members

## **Distribution System Planning**

Ian Hoogendam – DSP Manager
 Shauna Thomas – DSP Program Specialist
 Daniel Talbot – DSP Engineer
 Cadogan Morgan – DSP Engineer
 John Rush – Project Manager
 Ryan Harvey – CBRE Product Manager

## Local Pendleton Team

Doug Guttromson– Field Engineer
 Lori Wyman– Regional Business Manager

- Paul Howland Umatilla County
- John Shafer Umatilla County
- Celinda A. Timmons Umatilla County
- Cheri Rosenberg-LaBoy Pendleton Chamber of Commerce
- Caryn Appler Energy Trust of Oregon
- Jim Cheney Hill Meat Company
- Rita Campbell Greater Eastern Oregon Development Corporation
- ➢ Kara Woolsey − Travel Pendleton
- Robb Corbett City of Pendleton Mayor
- John Turner City of Pendleton City Manager

## Workshop Objectives

## Success is a transparent, robust, and holistic distribution system planning framework.

## Education

- Explaining traditional solution approaches and nontraditional solution programs
- Development and comparison of solutions

#### Engagement

- Gathering input about the solutions being considered
- Understanding the needs, values, and concerns of the community

#### Transparency


- Involving the community throughout the process
- Sharing of processes, analysis results, decisions, and learnings

## Why are you here? What do you hope to get out of today's discussion?





## Electric Grid Overview



#### What is Oregon DSP?

- Advancements to traditional DSP based on guidelines proposed by Oregon PUC staff
- Increased transparency of DSP processes to meet the needs and leverage the capabilities of the modern grid

#### **Key Changes to Traditional DSP**


• Enhanced forecasting:

**DISTRIBUTION SYSTEM PLANNING** 

- 24-hour usage profiles
- 10-year forecast horizon
- Evaluation of <u>nontraditional solutions</u> to address grid needs
- Increased community engagement



#### Modern Grid



**Past Grid** 

## Distribution System Planning Studies vs. Ad-Hoc Studies


#### **Distribution System Planning Studies**

- Scheduled to be completed on a 5-year cycle
- 5–10-year planning horizon
- Schedule may shift depending on several factors (high load growth activity, large load additions, etc.)
- 99 planning studies are on 5-year cycle in Pacific Power service area
- Study process takes multiple months


## Ad-hoc Studies (Generation Interconnect or System Impact Study)

- Initiated by load, generation interconnection, or transmission service requests
- Focused on a limited area, and the immediate effects of the request on reliability and load service
- Shorter timeframes to meet customer needs (~120 days for initial study)
- Customer shares in solution costs and has input into what solutions are implemented

## 2024 DSP Study Process and Local Engagement Plan




## Types of Grid Needs



Equipment Upgrades	Increase capacity of system equipment	
New Equipment	New equipment to address voltage/protection needs or facilitate load transfers	
New Substations and Circuits	Sometimes required in conjunction with other traditional solutions	
Load Transfers	Transfer load to circuits with spare capacity	
Load Balancing	Balancing load among circuit wires	
Settings Changes	Update equipment settings to ensure safe and reliable service for expected loading conditions	

#### **Costs of Traditional Solutions from Recent Studies**



Solar	Accelerate solar adoption in area through marketing and incentives	
Energy Efficiency	Accelerate energy efficiency in area through marketing and incentives	energy ENERGY STAR
Demand Response	Lower peak demand by managing behind the meter devices: *Batteries, Smart Thermostats, Water Heaters, EV Charging	OFF-PEAK 9 PM 3 8 7 6 5
Partnerships	Collaboration with partners on unique/innovative solutions	MR. FUSION®

## Pacific Power Programs




#### **Optimal Time Rewards**

- Smart thermostat program
   Smart thermostat rebates through Energy Trust of Oregon
- Water heater program (multifamily only)
- >Initial enrollment incentive
- ➤Ongoing annual incentive

#### Commercial & Industrial Demand Response

enelx

- Commercial and Industrial customers agree to curtail load during peak events in exchange for financial incentives
- Incentives vary by:
  - Average available load for curtailment during product hours
  - ✤Advance notification timing



#### Time of Use Rate

- On-peak (5PM-9PM): about 28¢ per kilowatt-hour (kWh)
- ➢Off-peak: about 10¢ per kWh
- ➢ First year guarantee:
  - Bill will be no more than 10% more than it would have been under standard rate
- \*Standard combined effective rate 13.7¢ per kWh




## Community-Based Renewable Energy Pilot



## **Community-Based Renewable Energy (CBRE) Projects**

Allows community-level participation in a renewable energy source that promotes climate resilience as well as broader benefits. In Oregon, CBRE projects have three components:



## **Proposed CBRE-RH Pilot Components**

- 1. <u>TECHNICAL ASSESSMENTS</u>: Continue to provide feasibility studies (began in 2020) to communities interested in better understanding the costs and requirements of solar and battery energy storage systems at <u>critical community facilities</u>
- 2. ONGOING PROJECT SUPPORT: Leverage expertise and provide supplemental funding to support the planning for, and installation of, the battery storage component of <u>planned and existing resilience projects</u> to provide grid-enabled system-wide benefits and learning outcomes (capping the investment as part of the Pilot)
- **3. <u>GRANT MATCHING</u>**: Establish a mechanism to provide matching funds for communities seeking external grant awards for <u>resilience projects at critical facilities</u>



Provide a mechanism of support for communities that have yet to begin CBRE development

Aid in the interconnection of funded, in-flight resilience projects with grid-enabled storage to capture takeaways & learnings with:

2a) Design Support2b) Incentive Offering2c) Ongoing Data Collection



Assist communities as they take advantage of existing funding opportunities

18

POWERING YOUR GREATNESS



# Break (10 Mins)

Ti Start Timer

TIME TO RESUME





## Study Area Overview



## Pendleton Area Overview

#### **Distribution System**


- Substations: 6
- Circuits: 18
- Line miles: 1,356 miles (sum of pole-to-pole distance)
  - Overhead : 724 miles
  - Underground: 632 miles

#### **Customer Makeup**

- Residential: 11,093 meters
- Commercial: 2,136 meters
- Irrigation: 207 meters
- Industrial: 26 meters

#### **Other Characteristics**

- New substation (McKay 2022)
- Historically greatest electrical use in winter, but transitioning to summer
- System more constrained in summer




## Pendleton Area Percentage Peak Load by Customer Type


Different customer types have different use patterns.

Circuit peaks occur on different days and times depending on the types of customers served.



### **Pendleton Area Total**





## Pendleton Area Distribution Generation Growth

## **Distribution Net Energy Metering** only\*

**Solar: 60%** 

Advanced solar options: 14%


Ex: Solar & battery, solar aggregate, etc.

Multiple generation types: 15%

Ex: Wind & solar

**Micro-hydropower : 13%** 

\* As of Oct 2023



#### Pendleton Area Net Metered Distributed Generation


## DSP Map- Distribution Generation Readiness Layer

## **DSP Map**

The Distribution Generation (DG) Readiness Layer informs users of the ability to add large generation projects to a circuit.


Notable Pendleton Area Circuits:

- Two circuits primarily serve a single customer
- Three circuits are generation limited
- One circuit is categorized as DG Capacity Generally Available
  - Has substation equipment and capacity




## Elevated Fire Risk (EFR) Settings

- During the peak of the 2023 fire season
   24% of all overhead circuits were placed in EFR settings
- EFR settings are enabled across the service territory; well in advance of weather conditions that have historically been related to catastrophic fires
- PacifiCorp is still analyzing the data from the 2023 fire season to measure effectiveness; other utilities in California have experienced a 68% reduction in ignitions from fast trip settings




The proactive deployment of EFR settings is based on 30 years of utility related wildfires in the western U.S. and the weather conditions at the time of those fires

#### WILDFIRE IMPACT





Of catastrophic fires occur in the Red Area, which is Public Safety Power Shutoff conditions



**EFR** 


Is enabled when weather conditions reach **yellow for a given area** and stay on for FHCA throughout the fire season. Providing a safety buffer between enablement and when wildfire impacts are historically experienced

## Grid Protection Basics: Fuses

What is a fuse? What does it do?

A protection device designed to limit fault damage and outage effect









## Drivers for Load Growth

## What drivers of load growth have you seen in your community and where are they occurring?



Natural Gas/Diesel Prices

Policy

**Economic Output** (Gross County Product)




## Pendleton Area Load Growth Forecast

DSP load forecasts use additional data, weather normalization and a longer time window compared to traditional methods

Substation	Summer	Winter
Athena	0.5 %	0.3 %
Buckaroo	1.8 %	1.5%
МсКау	2%	0.9%
Pendleton	0.1%	0.5%
Pilot Rock	0.3%	0.2%
Weston	0.2%	0.2%
OVERALL AVG	0.8%	0.7%

Annual growth rate through 2033




## **Athena - 5W703**

Potential substation capacity need

## **McKay - 5W856**

Potential substation capacity need

Potential wire need




## Preliminary Grid Needs: 5W703

## Capacity grid need:

 Potential overload of substation equipment in 5 years

## **Potential traditional solutions:**

- Equipment upgrade
  - Check substation ratings
- Load transfer (preferred option)
   Check connection to other circuits
   Check adjacent circuit loading
   Check transmission loading




## Potential Nontraditional Solutions

## **DSP non-traditional solution guidelines\*:**


- Time: forecasted grid need occurs in 5-10 years
- Cost: traditional solution cost > \$250k
- \*Guidelines have some flexibility

## Additional steps to determine viability:

Check peak time and grid need amount
 Check customer type, count and load patterns
 Check PV output for peak time and location
 Compare PV vs storage amounts
 Check existing offers for energy efficiency or time of use rates








## Preliminary Grid Needs: 5W856

## **Capacity grid need:**

- Modeled wire capacity need (Summer 2024)
- Potential substation equipment capacity need (Summer 2027)

## **Potential traditional solutions:**

- Wire need
  - Reconductor
  - Load transfer
- Substation need
  - Load transfer
  - Can't upgrade because of general substation limits





# Next Steps/Open Discussion





## **Conclusion:**

We have identified preliminary grid needs in this study area. The feedback we have received today, and further study will guide our project proposals.

Non-traditional solutions could be cost effective and benefit many parties. Thank you for engaging in the discussion today.



## Questions/Comments?







## Additional DSP Information

## **DSP Email / Distribution List Contact Information**

<u>DSP@pacificorp.com</u>

## **DSP Webpages**

- <u>Pacific Power Oregon DSP Website</u>
- DSP Map
- Planificación del Sistema de Distribución de Oregón (pacificorp.com)

## **Additional Resources**

- PacifiCorp's DSP Part 1 Report
- <u>PacifiCorp's DSP Part 2 Report</u>
- DSP Pilot Project Suggestion Form
- PacifiCorp Wildfire Mitigation Plans
- <u>Energy Trust of Oregon</u>
- Optimal Time Rewards (pacificpower.net)
- <u>Commercial & Industrial Demand Response (pacificpower.net)</u>
- Time of Use (pacificpower.net)



## Thank you!






## Appendix



Pendleton Reliability






#### **DISTRIBUTION SYSTEM PLANNING**

42

#### Pendleton Commercial And Residential Meter Growth



10 Year Meter Growth ('14—'24): 981 for Res, 297 for Commercial and 0 for Industrial 2 Year Meter Growth ('22-'24): 677 for Res, 181 for Commercial

#### **DISTRIBUTION SYSTEM PLANNING**

cia

ຄົ