

***Weber Hydroelectric Project
FERC No. 1744
Comments on Preliminary Draft Water Resources Technical Report
Submitted to the Water Resources Working Group for 30-day Review 3/15/2017***

Technical Report	Commenter (initials/ agency)	Section Title/ Paragraph	Comment	Resolution
Water Quality				
	KL/UDWQ	Section 5.1.5 Turbidity	I suggest also looking at the change in turbidity between site WR03 and WR04. For the 3A cold water fishery, the turbidity standard states that the turbidity increase must be less than or equal to 10 NTUs. Looking at the average change between those two sites may also provide compelling information.	Added discussion of this standard and comparison between sites. Also added clarification on averages.
	KL/UDWQ	Section 5.1.1 Temperature	I suggest also looking at the change in temperature between site WR03 and WR04. For the 3A cold water fishery, the temperature standard states that the maximum temperature change is 2°C.	Added discussion of this standard and comparison between sites.
	PT/UDWR	N/A	The Utah Division of Wildlife Resources has reviewed the Draft Water Resource Technical Report for PacifiCorp's Weber Hydroelectric Project Re-licensing ALP. We have no comments on the plan and we recommend approval. We thank you for the opportunity to review this plan.	N/A