

# PacifiCorp - Stakeholder Feedback Form

## 2021 Integrated Resource Plan

PacifiCorp (the Company) requests that stakeholders provide feedback to the Company upon the conclusion of each public input meeting and/or stakeholder conference calls, as scheduled. PacifiCorp values the input of its active and engaged stakeholder group, and stakeholder feedback is critical to the IRP public input process. PacifiCorp requests that stakeholders provide comments using this form, which will allow the Company to more easily review and summarize comments by topic and to readily identify specific recommendations, if any, being provided. Information collected will be used to better inform issues included in the 2021 IRP, including, but not limited to the process, assumptions, and analysis. In order to maintain open communication and provide the broader Stakeholder community with useful information, the Company will generally post all appropriate feedback on the IRP website unless you request otherwise, below.

Date of Submittal 2020-08-28

\*Name: Brian Muir

Title: City Administrator

\*E-mail: bmuir@kemmerer.org

Phone: (307) 466 - 3128

\*Organization: City of Kemmerer

Address: City Hall

City: Kemmerer

State: WY

Zip: 83101

Public Meeting Date comments address:  Check here if not related to specific meeting

List additional organization attendees at cited meeting:

---

**\*IRP Topic(s) and/or Agenda Items:** List the specific topics that are being addressed in your comments.

Natural Gas Elevation Efficiency

Check here if any of the following information being submitted is copyrighted or confidential.

Check here if you do **not** want your Stakeholder feedback and accompanying materials posted to the IRP website.

---

**\*Respondent Comment:** Please provide your feedback for each IRP topic listed above.

Natural Gas Elevation Efficiency Studies--You mentioned in your IRP meeting that you are studying the efficiency of natural gas at various elevations. Your maximum elevation you said you would study is 6500. Please note that the Naughton #1 and #2 and #3 plants are actually at 6950. We ask that you give these study these plants as well at this elevation, especially given that you current have #3 running on natural gas.

### **PacifiCorp Response:**

Thank you for your feedback. The Company will evaluate your suggestion as the supply side resource table and cases are developed and discussed as part of the 2021 Integrated Resource Plan (IRP) public input meeting series. The company's assessment of elevation is intended to capture a reasonable range across different parts of the system. It is not feasible to explicitly assess elevations for specific sites and locations when evaluating proxy resources in the IRP.

---

**Data Support:** If applicable, provide any documents, hyper-links, etc. in support of comments. (i.e. gas forecast is too high - this forecast from EIA is more appropriate). If electronic attachments are provided with your comments, please list those attachment names here.

---

**Recommendations:** Provide any additional recommendations if not included above - specificity is greatly appreciated.

---

\* Required fields

---

Please submit your completed Stakeholder Feedback Form via email to [IRP@PacifiCorp.com](mailto:IRP@PacifiCorp.com)

Thank you for participating.

\* Required fields