

# PacifiCorp - Stakeholder Feedback Form

## 2021 Integrated Resource Plan

PacifiCorp (the Company) requests that stakeholders provide feedback to the Company upon the conclusion of each public input meeting and/or stakeholder conference calls, as scheduled. PacifiCorp values the input of its active and engaged stakeholder group, and stakeholder feedback is critical to the IRP public input process. PacifiCorp requests that stakeholders provide comments using this form, which will allow the Company to more easily review and summarize comments by topic and to readily identify specific recommendations, if any, being provided. Information collected will be used to better inform issues included in the 2021 IRP, including, but not limited to the process, assumptions, and analysis. In order to maintain open communication and provide the broader Stakeholder community with useful information, the Company will generally post all appropriate feedback on the IRP website unless you request otherwise, below.

Date of Submittal 2020-09-17

\*Name: Brian Muir

Title:

\*E-mail: bmuir@kemmerer.org

Phone: (307) 466 - 3128

\*Organization: City of Kemmerer

Address: City Hall Kemmerer Wyoming 83101

City: Kemmerer

State: WY

Zip: 83101

Public Meeting Date comments address:  Check here if not related to specific meeting

List additional organization attendees at cited meeting:

---

**\*IRP Topic(s) and/or Agenda Items:** List the specific topics that are being addressed in your comments.

Study of Gas Efficiency at various elevations

Check here if any of the following information being submitted is copyrighted or confidential.

Check here if you do **not** want your Stakeholder feedback and accompanying materials posted to the IRP website.

---

**\*Respondent Comment:** Please provide your feedback for each IRP topic listed above.

In a previous IRP document it mentioned studying natural gas efficiency at various elevations. The maximum elevation you listed was 6500, which would make it so you would not study the efficiency of natural gas in Kemmerer Wyoming which is almost 7,000 feet. Please also study at our elevation.

### **PacifiCorp Response:**

The 6,500 feet elevation for natural gas resources are representative of Kemmerer, Wyoming. Increasing elevation causes little or no change in the efficiency of both simple cycle and combined cycle combustion turbine-generators. Increasing elevation causes combustion turbine-generator production to decrease at a rate of about three percent per 1,000 feet of elevation. Changes in elevation cause little or no change in efficiency and production for reciprocating engines.

---

**Data Support:** If applicable, provide any documents, hyper-links, etc. in support of comments. (i.e. gas forecast is too high - this forecast from EIA is more appropriate). If electronic attachments are provided with your comments, please list those attachment names here.

---

**Recommendations:** Provide any additional recommendations if not included above - specificity is greatly appreciated.

---

\* Required fields

---

Please submit your completed Stakeholder Feedback Form via email to [IRP@PacifiCorp.com](mailto:IRP@PacifiCorp.com)

Thank you for participating.

\* Required fields