



2020 Renewable Resources Assessment



PacifiCorp

2020 Renewable Resources Assessment Project No. 125017

> Revision 1 August 2020



2020 Renewable Resources Assessment

prepared for

PacifiCorp 2020 Renewable Resources Assessment Salt Lake City, Utah

Project No. 125017

Revision 1 August 2020

prepared by

Burns & McDonnell Engineering Company, Inc. Kansas City, Missouri

COPYRIGHT © 2020 BURNS & McDONNELL ENGINEERING COMPANY, INC.

TABLE OF CONTENTS

Page No.

1.0	INTRODUCTION					
	1.1	Evaluated Technologies1-1				
	1.2	Assessment Approach1-1				
	1.3	Statement of Limitations1-2				
2.0	STU	DY BASIS AND ASSUMPTIONS2-1				
	2.1	Scope Basis				
	2.2	General Assumptions				
	2.3	EPC Project Indirect Costs				
	2.4	Owner Costs				
	2.5	Cost Estimate Exclusions				
	2.6	Operating and Maintenance Assumptions				
3.0	SOLAR PHOTOVOLTAIC					
	3.1	PV General Description				
	3.2	PV Performance				
	3.3	PV Cost Estimates				
	3.4	PV O&M Cost Estimate				
	3.5	PV Plus Storage				
4.0	ON-S	ON-SHORE WIND				
	4.1	Wind Energy General Description				
	4.2	Wind Performance				
	4.3	Wind Cost Estimate				
	4.4	Wind Energy O&M Estimates				
	4.5	Wind Energy Production Tax Credit				
	4.6	Wind Plus Storage				
5.0	PUM	IPED HYDRO ENERGY STORAGE				
	5.1	General Description				
	5.2	PHES Cost Estimate				
6.0	COMPRESSED AIR ENERGY STORAGE					
	6.1	General Description				
		6.1.1 Diabatic CAES				
		6.1.2 Adiabatic CAES				
	62	CAES Cost Estimates 6-2				
	0.2					

7.0 LIQUID AIR ENERGY STORAGE		D AIR E	NERGY STORAGE	7-1
	7.1	General	Description	. 7-1
		7.1.1	System Charging – Air Liquefaction	. 7-3
		7.1.2	Energy Storage – Liquid Air Storage	. 7-3
		7.1.3	System Discharge – Power Generation	. 7-4
8.0	GRA\	/ITY ENI	ERGY STORAGE	8-1
	8.1	General	Description	. 8-1
		8.1.1	Vertical Shaft Gravity Energy Storage	. 8-1
		8.1.2	Crane-Lift Gravity Energy Storage	. 8-2
		8.1.3	Rail Energy Storage	. 8-1
9.0	BATT	ERY ST	ORAGE TECHNOLOGY	9-2
	9.1	General	Description	. 9-2
		9.1.1	Flow Batteries	. 9-2
		9.1.2	Conventional Batteries	. 9-3
		9.1.3	High Temperature Batteries	. 9-4
	9.2 Battery Emissions Controls		. 9-4	
9.3 Battery Storage Performance		Storage Performance	. 9-4	
	9.4	Regulato	ory Trends	. 9-5
	9.5	Battery S	Storage Cost Estimate	. 9-6
	9.6	Battery S	Storage O&M Cost Estimate	. 9-6
10.0	CONC	CLUSION	NS1	0-1
APPE APPE	NDIX /	A – SUM B – SOL	MARY TABLES AR PVSYST MODEL OUTPUT (5MW)	

APPENDIX C – SOLAR OUTPUT SUMMARY

APPENDIX D – WIND PERFORMANCE INFORMATION

APPENDIX E – DECLINING COST CURVES

APPENDIX F – GENERATION CASHFLOWS

1.0 INTRODUCTION

PacifiCorp (Owner) retained Burns & McDonnell Engineering Company (BMcD) to evaluate various renewable energy resources in support of the development of the Owner's 2020 Integrated Resource Plan (IRP) and associated resource acquisition portfolios and/or products. The 2020 Renewable Resources Assessment (Assessment) is screening-level in nature and includes a comparison of technical capabilities, capital costs, and O&M costs that are representative of renewable energy and storage technologies listed below.

It is the understanding of BMcD that this Assessment will be used as preliminary information in support of the Owner's long-term power supply planning process. The level of detail in this study is sufficient to provide screening level data required for the IRP planning process. Past the IRP modeling and selection, technologies of interest to the Owner should be further investigated in order to refine design, major equipment selection, value engineering, and specific project scope adjustments.

1.1 Evaluated Technologies

- Single Axis Tracking Solar
- Onshore Wind
- Energy Storage
 - Pumped Hydro Energy Storage (PHES)
 - Compressed Air Energy Storage (CAES)
 - o Lithium Ion Battery
 - o Flow Battery
- Solar + Energy Storage
- Wind + Energy Storage

1.2 Assessment Approach

This report accompanies the Renewable Resources Assessment spreadsheet files (Summary Tables) provided by BMcD. The Summary Tables are broken out into three separate files for Solar, Wind, and Energy Storage options. The costs are expressed in mid-2020 dollars for a fixed price, turn-key resource implementation. The Summary Tables can be found in Appendix A: Summary Tables.

This report compiles the assumptions and methodologies used by BMcD during the Assessment. Its purpose is to articulate that the delivered information is in alignment with PacifiCorp's intent to advance its resource planning initiatives.

1.3 Statement of Limitations

Estimates and projections prepared by BMcD relating to performance, construction costs, and operating and maintenance costs are based on experience, qualifications, and judgment as a professional consultant. BMcD has no control over weather, cost and availability of labor, material and equipment, labor productivity, construction contractor's procedures and methods, unavoidable delays, construction contractor's method of determining prices, economic conditions, government regulations and laws (including interpretation thereof), competitive bidding and market conditions or other factors affecting such estimates or projections. Actual rates, costs, performance ratings, schedules, etc., may vary from the data provided.

2.0 STUDY BASIS AND ASSUMPTIONS

2.1 Scope Basis

Scope and economic assumptions used in developing the Assessment are presented below. Key assumptions are listed as footnotes in the summary tables, but the following expands on those with greater detail for what is assumed for the various technologies.

2.2 General Assumptions

The assumptions below govern the overall approach of the Assessment:

- All estimates are screening-level in nature, do not reflect guaranteed costs, and are not intended for budgetary purposes. Estimates concentrate on differential values between options and not absolute information.
- All information is preliminary and should not be used for construction purposes.
- All capital cost and O&M estimates are stated in mid-2020 US dollars (USD). Escalation is excluded.
- Estimates assume an Engineer, Procure, Construct (EPC) fixed price contract for project execution.
- Unless stated otherwise, all wind and solar options are based on a generic site with no existing structures or underground utilities and with sufficient area to receive, assemble and temporarily store construction material. Battery options are assumed to be located on existing Owner land.
- Sites are assumed to be flat, with minimal rock and with soils suitable for spread footings.
- Wind and solar technologies were evaluated across five states within Owner's service areas: Washington, Oregon, Idaho, Utah, and Wyoming. The specific locations within each state for potential wind/solar sites were determined by Owner.
- All performance estimates assume new and clean equipment. Operating degradation is excluded.
- Electrical scope is assumed to end at the high side of the generator step up transformer (GSU) unless otherwise specified in the summary table (most notably for CAES and PHES).
- Demolition costs were included for technology options with a shorter life cycle (Li-Ion, Solar, and Wind). Costs were developed based on Burns & McDonnell experience as well as published information. Recycling costs are included in the demolition figures; however, re-sale value of materials is excluded as that can vary significantly depending on metals pricing and competition in the currently expanding recycling market.

The current market is being impacted by various trade tariffs on materials as well as on solar modules. Predicting future trends or impacts of these tariffs is beyond the scope of this study. This 2020 study has based costs on recent bids that have accounted for the additional costs associated with current tariffs when available. While these costs are intended to represent a snapshot of 2020 pricing, additional volatility could occur when looking at future pricing of these options. These factors may also change the declining costs curves presented in the appendices.

Energy storage technologies evaluated in this assessment are expected to take advantage of less expensive, off-peak power to charge the system to later be used for generation during periods of higher demand. These storage options provide the ability to optimize the system for satisfying monthly, or even seasonal, energy needs. Energy stored off-peak and delivered on-peak can help reduce on-peak prices and is therefore beneficial to consumers. Additionally, energy storage has a direct benefit to renewable resources as it is able to absorb excess energy that otherwise would need to be curtailed due to transmission constraints. This could increase the percentage of power generated by clean technologies and delivered during peak hours. Costs and options shown in this assessment represent storage technologies that are designed for one full cycle per day in a scheduled use case. Other use cases such as frequency regulation, voltage regulation, renewable smoothing, renewable firming, and black starting are not accounted for in the options presented in this study. Different use cases will impact the capital cost, O&M, and performance of the various technologies. EPC Project Indirect Costs

The following project indirect costs are included in capital cost estimates:

- Construction/startup technical service
- Engineering and construction management
- Freight
- Startup spare parts
- EPC fees & contingency

2.3 Owner Costs

Allowances for Owner's costs are included in the pricing estimates. The cost buckets for Owner's costs varies slightly by technology but is broken out in the summary tables in Appendix A: Summary Tables.

2.4 Cost Estimate Exclusions

The following costs are excluded from all estimates:

• Financing fees

- Interest during construction (IDC)
- Escalation
- Performance and payment bond
- Sales tax
- Property taxes and insurance
- Off-site infrastructure
- Utility demand costs
- Salvage values

2.5 Operating and Maintenance Assumptions

Operations and maintenance (O&M) estimates are based on the following assumptions:

- O&M costs are based on a greenfield facility with new and clean equipment.
- O&M costs are in mid-2020 USD.
- Property taxes allowance included for solar and onshore wind options.
- Land lease allowance included for PV and onshore wind options.
- Li-Ion battery O&M includes costs for additional cells to be added over time.

3.0 SOLAR PHOTOVOLTAIC

This Assessment includes 100 MW, and 200 MW single axis tracking photovoltaic (PV) options evaluated at two locations within the PacifiCorp services area.

3.1 PV General Description

The conversion of solar radiation to useful energy in the form of electricity is a mature concept with extensive commercial experience that is continually developing into a diverse mix of technological designs. PV cells consist of a base material (most commonly silicon), which is manufactured into thin slices and then layered with positively (i.e. Phosphorus) and negatively (i.e. Boron) charged materials. At the junction of these oppositely charged materials, a "depletion" layer forms. When sunlight strikes the cell, the separation of charged particles generates an electric field that forces current to flow from the negative material to the positive material. This flow of current is captured via wiring connected to an electrode array on one side of the cell and an aluminum back-plate on the other. Approximately 15% of the solar energy incident on the solar cell can be converted to electrical energy by a typical silicon solar cell. As the cell ages, the conversion efficiency degrades at a rate of approximately 2% in the first year and 0.5% per year thereafter. At the end of a typical 30-year period, the conversion efficiency of the cell will still be approximately 80% of its initial efficiency.

3.2 PV Performance

BMcD pulled Typical Meteorological Year (TMY) weather data for each site to determine expected hourly irradiance. BMcD then ran simulations of each PV option using PVSYST software. The resultant capacity factors for single axis tracking systems are shown in the Summary Tables. Inverter loading ratios (ILR) for each base plant nominal output at the point of electrical interconnect are indicated in Table 3-1.

Nominal Output	Single-Axis Tracking (SAT) DC/AC Ratio	
100 MW	1.30	
200 MW	1.30	

Table 3-1: Inverter Loading Ratios in Assessment

There are different panel technologies which may exhibit different performance characteristics depending on the site. This assessment assumes poly-crystalline panels. The alternative, thin film technologies, are typically cheaper per panel, but they are also less energy dense, so it's likely that more panels would be required to achieve the same output. In addition, the two technologies respond differently to shaded conditions. The two technologies are also impacted differently by current solar tariffs which has also impacted availability of the two.

Appendix B: Solar PVSYST Model Output (5MW) shows the PVSYST model output for a 4.2 MW block with the input assumptions, losses, and output summary. Appendix C: Solar Output Summary shows an additional output summary page unique for each solar option size and location. TMY data for each site as well as PVSYST 8760 outputs are provided to accompany this report outside of the formal report appendices.

3.3 PV Cost Estimates

Cost estimates were developed using in-house information based on BMcD project experience as an EPC contractor as well as an Owner's Engineer for EPC solar projects. Cost estimates assume an EPC project plus typical Owner's costs. A typical solar project cash flow is included in Appendix F: Generation Cash Flows.

PV cost estimates for the single axis tracking systems are included in the Summary Tables. Costs are based on the DC/AC ratios in Table 4-1 above, and \$/kW costs, based on the nominal AC output, are shown in Appendix A: Summary Tables. The project scope assumes a high voltage interconnection for both the 100 and 200 MW options. Owner's costs include a switchyard allowance for the larger scale options, but no transmission upgrade costs or high voltage transmission interconnect line costs are included.

PV installed costs have steadily declined for years. The main drivers of cost decreases include substantial module price reductions, lower inverter prices, and higher module efficiency. However, recent US tariffs have had an impact on PV panels and steel imports. Pricing in the summary table is based on actual competitive EPC market quotes since these tariffs have been in place to take into account this impact. The panel tariffs only impact crystalline solar modules, however the availability of CdTe is limited for the next couple years, so it is prudent to assume similar cost increases for thin film panels until the impacts of the tariff are clearer.

Demolition costs for PV are included in the IRP Inputs and are meant to reflect the end of life decommissioning efforts. PV recycling in the U.S. is led by the Solar Energy Industries Association (SEIA), which has developed a national PV recycling program. This program works with several recycling companies along with regulators in order to abide by the Federal Resource Conservation and Recovery Act (RCRA), which is the governing legislation for the disposal of PV equipment. SEIA advises system owners to consider reuse and refurbishment when possible. However, when demolition

and recycling is required, PV panels contain several materials that can be recovered. By weight, 80% of the panel consists of glass and aluminum. Other valuable materials include copper, silver, and semiconductor materials. Similar to the Li-Ion storage industry, many PV sites have not yet reached their end of useful life and therefore the recycling and materials resale market is still in its infancy.

The 2020 Assessment excludes land costs from capital and Owner costs. It is assumed that all PV projects will be on leased land with allowances provided in the O&M costs.

3.4 PV O&M Cost Estimate

O&M costs for the PV options are shown in the Summary Tables. O&M costs are derived from BMcD project experience and vendor information. The 2020 Assessment includes allowances for land lease and property tax costs.

The following assumptions and clarifications apply to PV O&M:

- O&M costs assume that the system is remotely operated and that all O&M activities are performed through a third-party contract. Therefore, all O&M costs are modeled as fixed costs, shown in terms of \$MM per year.
- Land lease and property tax allowances are included based on in house data from previous projects.
- Equipment O&M costs are included to account for inverter maintenance and other routine equipment inspections.
- BOP costs are included to account for monitoring & security and site maintenance (vegetation, fencing, etc.).
- Panel cleaning and snow removal are not included in O&M costs.
- The capital replacement allowance is a sinking fund for inverter replacements, assuming they will be replaced once during the project life. It is a 15-year levelized cost based on the current inverter capital cost.

3.5 PV Plus Storage

The PV plus storage options combine the PV technology discussed in section 3.0 with the lithium ion batteries described in section 9.0. The battery storage size is set at approximately 50% of the total nominal output of the base solar options, with four hours of storage duration.

The storage system is assumed to be electrically coupled to the PV system on the AC side, meaning the PV and storage systems have separate inverters. However, there are use cases such as PV clipping that

may be better served by a DC-DC connection. In a DC coupled system, the storage side would have a DC-DC voltage converter and connect to the PV system upstream of the DC-AC inverters. For a clipping application, a DC-DC connection allows the storage system to capture the DC output from the PV modules that may have otherwise been clipped by the inverters. Further study beyond the scope of this assessment would be required to determine the best electrical design for a particular application or site, but at this level of study, the capital costs provided are expected to be suitable for either AC or DC coupled systems.

Capital costs are show as add-on costs, broken out as project and owner's costs. These represent the additional capital above the PV base cost, intended to capture modest savings to account for shared system costs such as transformer(s) and switchgear. In addition, overlapping owner costs are eliminated or reduced. Finally, a line for O&M add-on costs is also included which can be added with the base PV O&M costs to determine overall facility O&M.

As with the Li-Ion battery options, the co-located storage option assumes an operation profile of one cycle per day, which is used for calculating the O&M costs.

3-4

4.0 ON-SHORE WIND

4.1 Wind Energy General Description

Wind turbines convert the kinetic energy of wind into mechanical energy, which can be used to generate electrical energy that is supplied to the grid. Wind turbine energy conversion is a mature technology and is generally grouped into two types of configurations:

- Vertical-axis wind turbines, with the axis of rotation perpendicular to the ground.
- Horizontal-axis wind turbines, with the axis of rotation parallel to the ground.

Over 95 percent of turbines over 100 kW are horizontal-axis. Subsystems for either configuration typically include the following: a blade/rotor assembly to convert the energy in the wind to rotational shaft energy; a drive train, usually including a gearbox and a generator; a tower that supports the rotor and drive train; and other equipment, including controls, electrical cables, ground support equipment and interconnection equipment.

Wind turbine capacity is directly related to wind speed and equipment size, particularly to the rotor/blade diameter. The power generated by a turbine is proportional to the cube of the prevailing wind, that is, if the wind speed doubles, the available power will increase by a factor of eight. Because of this relationship, proper siting of turbines at locations with the highest possible average wind speeds is vital.

Appendix D: Wind Performance Information includes NREL wind resource maps for Idaho, Oregon, Utah, Washington, and Wyoming with the locations of interest marked as provided by Owner.

4.2 Wind Performance

This Assessment includes 200 MW onshore wind generating facilities in Idaho, Oregon, Utah, Washington, and Wyoming service areas. BMcD relied on publicly available data and proprietary computational programs to complete the net capacity factor characterization. Generic project locations were selected within the area specified by Owner.

The Vestas V150-4.0 wind turbine model were assumed for this analysis. The respective nameplate capacity, rotor diameter, and a hub height are provided in the Table 4-1. The maximum tip height of this package is under 500 feet, which means there are less likely to be conflicts with the Federal Aviation Administration (FAA) altitudes available for general aircraft. A generic power curve at standard atmospheric conditions for each of the sites was assumed for the V150-4.0. Note that this turbine is intended only to be representative of a typical International Electrotechnical Commission wind turbine.

Because this analysis assumes generic site locations, the turbine selection is not optimized for a specific location or condition. Actual turbine selection requires further site-specific analysis.

	Vestas V150-4.0
Name Plate Capacity, MW	4.0
Rotor Diameter, meters	150
Hub Height, meters	105

Table 4-1: Summary of Wind Turbine Model Information

Using the NREL wind resource maps, the mean annual hub height wind speed at each potential project location was estimated and then extrapolated using the wind profile power law for the appropriate hub height to determine a representative wind speed. Using a Rayleigh distribution and power curve for the turbine technology described above, a gross annual capacity factor (GCF) was subsequently estimated for each site for both turbine types.

Annual losses for a wind energy facility were estimated at approximately 17 percent, which is a common assumption for screening level estimates in the wind industry. This loss factor was applied to the gross capacity factor estimates to derive a net annual capacity factor (NCF) for each potential site. Ideally, a utility-scale generation project should have an NCF of 30 percent or better. The NCF estimates for the PacifiCorp service areas are shown in the Summary Tables and represent an average of the two evaluated technologies.

4.3 Wind Cost Estimate

The wind energy cost estimate is shown in the Summary Tables. A typical cash flow for a wind project is included in Appendix F: Generation Cash Flows. Cost estimates assume an EPC project plus typical Owner's costs. Costs are based on a 200 MW plant with 4.0 MW turbines (50 total turbines) and 105-meter hub heights.

- Equipment and construction costs are broken down into subcategories per PacifiCorp's request. These breakouts represent the general scale of a 200 MW wind project but are not intended to indicate the expected scope for a specific site.
- The EPC scope includes a GSU transformer for interconnection at 161 kV.

• Land costs are excluded from the EPC and Owner's cost. For the 2020 Study, it is assumed that land is leased, and those costs are incorporated into the O&M estimate. Cost estimates also exclude escalation, interest during construction, financing fees, off-site infrastructure, and transmission.

Demolition costs shown on the IRP Input Table are meant to represent the efforts to return the project site back to native conditions (i.e. re-grading the site to achieve suitable drainage and seeding disturbed areas consistent with surrounding areas). This includes the decommissioning and demolition of all wind turbines as well as the associated infrastructure (i.e. buildings, turbine foundations, access roads, transmission lines, etc.). Also included is the transportation cost associated with moving the turbines offsite to recycling or landfill locations. Demolishing turbine blades can be a difficult as they are made of tough resin and fiberglass. One method of decommissioning is to cut the blades up into 3 or more parts to make them easier to transport to landfills. Another method involves grinding the blades into small pellets that can used for decking, pallets, and piping. Along with PV and li-ion storage, wind turbines contain valuable components such as steel, copper, and other metals that ideally can be resold as part of the recycling process.

4.4 Wind Energy O&M Estimates

O&M costs in the Summary Tables are derived from in-house information based on BMcD project experience and vendor information. Wind O&M costs are modeled as fixed O&M, including all typical operating expenses including:

- Labor costs
- Turbine O&M
- BOP O&M and other fixed costs (G&A, insurance, environmental costs, etc.)
- Property taxes
- Land lease payments

A summary of the suggested planned maintenance activities for a utility-scale wind energy facility are presented in Table 4-2 below. These represent the minimum activities that Burns & McDonnell suggests to be performed on a recurring basis and represent a minimum standard of performance if high availability and/or extended useful life are required. For the avoidance of doubt, the frequencies noted in Table 4-2 represent a minimum recurrence interval; trending results, condition-based monitoring data, supplier recommendations, or other similar items may necessitate more frequent planned maintenance.

Component	Activity	Min. Frequency
	Visual inspection of exterior components (e.g., nacelle, tower, blades)	Semi-annual
	Tower weld inspections	3-year rotation
- ·	External paint touch-up	As required
General	Fastener inspections and re-torque	3-year rotation
	Condition monitoring system set-point review	Annual
	Supplier-recommended semi-annual maintenance	Semi-annual
	Monitoring via SCADA	24/7
	Visual inspection of internal components	Per supplier manuals
	Functional tests of major components	Per supplier manuals
	Gearbox borescope inspections	3-year rotation
	Gearbox oil sampling and trending	Annual
Nacelle	Gearbox oil and filter replacement	Per supplier manuals
	Bearing grease sampling and trending (e.g., main bearing, yaw bearings, blade bearings)	Per supplier manuals
	Lubrication flush and filter replacement	Per supplier manuals
	Inspection of emergency equipment	Annual
Foundations	Visual inspection of exterior components (including bolts, nuts, washers, concrete, and surroundings)	Semi-annual
	Re-application of anti-corrosion protective coating	As required
	Visual inspection of infrastructure (e.g., roads, collection routes, gen-tie routes, substation)	Annual
	Visual inspection of electrical equipment (e.g., transformers, breakers)	Semi-annual
	Maintain drainage away from foundations / structures	As required
DOD	Transformer oil testing and trending	Annual
ROL	Infrared scanning on all transformers	Annual
	De-energized substation maintenance	3 years
	Revenue meter test / calibration	Semi-annual
	Visual inspection of met towers (including tower, instruments, and guys)	Annual
	Met tower instrument calibration	Bi-annual

Table 4-2: Minimum Wind Farm Planned Maintenance Activities

An allowance for capital replacement costs is not included within the annual O&M estimate in the Summary Table. A capital expenditures budget for a wind farm is generally a reserve that is funded over the life of the project that is dedicated to major component failures. An adequate capital expenditures

budget is important for the long-term viability of the project, as major component failures are expected to occur, particularly as the facility ages.

If a capital replacement allowance is desired for planning purposes, Table 4-3 shows indicative budget expectations as a percentage of the total operating cost. As with operating expenses, however, these costs can vary with the type, size, or age of the facility, and project-specific considerations may justify deviations in the budgeted amounts.

Operational Years	Capital Expenditure Budget
0-2	None (warranty)
3 – 5	3% - 5%
6 - 10	5% - 10%
11-20	10% - 15%
21 - 30	15% - 20%
31-40	20% - 25%

Table 4-3: Summary of Indicative Capital Expenditures Budget by Year

4.5 Wind Energy Production Tax Credit

Tax credits such as the production tax credit (PTC) and investment tax credit (ITC) are not factored into the cost or O&M estimates in this Assessment, but an overview of the PTC is included below for reference.

To incentivize wind energy development, the PTC for wind was first included in the Energy Policy Act of 1992. It began as a \$15/MWh production credit and has since been adjusted for inflation, currently worth approximately \$25/MWh.

The PTC is awarded annually for the first 10 years of a wind facility's operation. Unlike the ITC that is common in the solar industry, there is no upfront incentive to offset capital costs. The PTC value is calculated by multiplying the \$/MWh credit times the total energy sold during a given tax year. At the end of the tax year, the total value of the PTC is applied to reduce or eliminate taxes that the owners would normally owe. If the PTC value is greater than the annual tax bill, the excess credits can potentially go unused unless the owner has a suitable tax equity partner.

Since 1992, the changing PTC expiration/phaseout schedules have directly impacted market fluctuations, driving wind industry expansions and contractions. The PTC is currently available for projects that begin construction by the end of 2020, but with a phaseout schedule that began in 2017. Projects that started construction in 2015 and 2016 will receive the full value of the PTC, but those that start(ed) construction in later years received reduced credits:

- 2017: 80% of the full PTC value
- 2018: 60% of the full PTC value
- 2019: 40% of the full PTC value
- 2020: 40% of the full PTC value (extended through Dec 31st, 2020)

To avoid receiving a reduction in the PTC, a "Safe Harbor" clause allowed for developers to avoid the reduction through an upfront investment in wind turbines by the end of 2016. The Safe Harbor clause allowed for wind projects to be considered as having begun construction by the end of the year if a minimum of 5% of the project's total capital cost was incurred before January 1st, 2017.

Many wind farms were planned for construction and operation when it was assumed they would receive 100% of the PTC. However, with the reduction in the PTC, some of these projects are no longer financially viable for developers to operate. This may result in renegotiated or canceled PPAs, or transfers to utilities for operation.

4.6 Wind Plus Storage

The wind plus storage options combine the wind technology discussed in section 4.0 with the lithium ion batteries described in section 9.0. The battery storage size is set at approximately 50% of the total nominal output of the base solar options, with four hours of storage duration. The storage system is assumed to be electrically coupled to the wind system on the AC side, meaning the storage system has its own inverter.

Capital costs are shown as add-on costs, broken out as project and owner's costs. These represent the additional capital above the wind base cost, intended to capture modest savings to account for shared system costs such as transformer(s) and switchgear. In addition, overlapping owner costs are eliminated or reduced. Finally, a line for O&M add-on costs is also included which can be added to the base wind O&M costs to determine overall facility O&M. As with the Li-Ion battery options, the co-located storage option assumes an operation profile of one cycle per day, which is used for calculating the O&M costs.

5.0 PUMPED HYDRO ENERGY STORAGE

5.1 General Description

Pumped-hydro Energy Storage (PHES) offers a way of storing off peak generation that can be dispatched during peak demand hours. This is accomplished using a reversable pump-turbine generator-motor where water is pumped from a lower reservoir to an upper reservoir using surplus off-peak electrical power. Energy is then recaptured by releasing the water back through the turbine to the lower reservoir during peak demand. To utilize PHES, locations need to be identified that have suitable geography near high-voltage transmission lines.

PHES provides the ability to optimize the system for satisfying monthly or even seasonal energy needs and PHES can provide spinning reserve capacity with its rapid ramp-up capability. Energy stored offpeak and delivered on-peak can help reduce on-peak prices and is therefore beneficial to consumers. PHES is well suited for markets where there is a high spread in day-time and night-time energy costs, such that water can be pumped at a low cost and used to generate energy when costs are considerably higher.

PHES also has the ability to reduce cycling of existing generation plants. Additionally, PHES has a direct benefit to renewable resources as it is able to absorb excess energy that otherwise would need to be curtailed due to transmission constraints. This could increase the percentage of power generated by clean technologies and delivered during peak hours.

5.2 PHES Cost Estimate

The PHES cost estimate was based on information provided by developers with limited scope definition. The costs were aligned as closely as possible based on the information provided. The reason information from developers was used versus using a generic site for PHES is due to the significant importance of geographical location for this type of energy storage. The cost estimate is shown in the Summary Tables. PHES can see life cycle benefits as their high capital cost is offset by long lifespan of assets.

6.0 COMPRESSED AIR ENERGY STORAGE

6.1 General Description

Compressed air energy storage (CAES) offers a way of storing off peak generation that can be dispatched during peak demand hours. CAES is a proven, utility-scale energy storage technology that has been in operation globally for over 30 years. CAES has two primary application methods: diabatic and adiabatic. To utilize CAES, the project needs a suitable storage site, either a salt cavern or mined hard-rock cavern. Salt caverns are the most preferred due to the low cavern construction costs, however mined hard-rock caverns are now a viable option in areas that do not have salt formations with the use of hydrostatic compensation to increase energy storage density and reduce the cavern volume required. CAES facilities use off-peak electricity to power a compressor train that compresses air into an underground reservoir at approximately 850 psig. Energy is then recaptured by releasing the compressed air, heating it, and generating power as the heated air travels through an expander.

6.1.1 Diabatic CAES

The difference between diabatic and adiabatic compressed air energy storage is in the method that the air is heated during generation. Diabatic CAES uses natural gas firing during generation via a gas turbine expansion train. Expansion train technology is also currently allowing for 30% H2 co-firing today and there are plans to develop the technology to support 100% H2. Round-trip efficiencies for diabatic CAES plants account for the energy input of the compressors as well as the energy input of the gas turbine. The energy input of the compressors is a design choice that will be made to balance cost and benefit. The round-trip efficiencies represented in this technology assessment are the efficiencies that can be reached at the cost that is shown. The heat input of the gas turbine during generation takes into account the heat rate of the turbine. The total energy output of the CAES plant is divided by the combination of these two figures (compressor energy and natural gas heat input) to calculate the round-trip efficiency. There have been two commercial CAES plants built and operated in the world. The first plant began commercial operations in 1978 and was installed near Huntorf, Germany. This 290 MW facility included major equipment by Brown, Boveri, and Company (BBC). The second is located near McIntosh, Alabama and is currently owned and operated by PowerSouth (originally by Alabama Electric Cooperative). This 110 MW facility began commercial operations in 1991 and employs Dresser Rand (DR) equipment. BMcD served as the Owner's engineer for this project. Diabatic CAES was removed from the evaluated options due to a shift in focus from developers to adiabatic CAES, which offers zero emissions storage.

6-1

6.1.2 Adiabatic CAES

A second application of compressed air energy storage is adiabatic, which uses no natural gas firing. Heat is recovered in a Thermal Energy Storage (TES) system while air is being compressed and this energy is released to heat the air during expansion and generation. During compression, air temperatures can reach up to 1000°F. The use of a TES (with oil, molten salt, etc..) to capture and release this heat allows the adiabatic CAES technology to work free of any fuel. This trait can decrease operating and construction costs. The absence of a gas turbine makes the calculation for round-trip efficiency the total energy output of the plant divided by the energy input of the compressors. Again, the size and energy requirements of the compressors is a design choice and the efficiencies represented in the technology assessment table are in conjunction with the costs also represented for each option. This technology is currently in service or in construction at 3 plants in Canada and Australia that total 25 MWh of storage capacity.

6.2 CAES Cost Estimates

The CAES cost estimates are shown in the Summary Tables. The costs were developed using generic Siemens and Hydrostor information that includes the power island, balance of plant and reservoir. Cost estimates assume an EPC project plus typical Owner's costs.

6.3 CAES Emissions Control

A Selective Catalytic Reduction (SCR) system is utilized in the diabatic CAES design along with demineralized water injection in the combustor to achieve NOx emissions of 2 parts per million, volumetric dry (ppmvd). A carbon monoxide (CO) catalyst is also used to control CO emissions to 2 ppmvd at the exit of the stack.

The use of an SCR and a CO catalyst requires additional site infrastructure. An SCR system injects ammonia into the exhaust gas to absorb and react with the exhaust gas to strip out NOx. This requires onsite ammonia storage and provisions for ammonia unloading and transfer. Adiabatic CAES is an emissions-free operation and does not require an emissions control system.

7.0 LIQUID AIR ENERGY STORAGE

7.1 General Description

Liquid air energy storage (LAES) uses electricity to drive a compression/refrigeration system that cools ambient air to approximately -320 °F, at which point it becomes a liquid. Liquefying air is advantageous because it achieves a volume reduction of approximately 700:1, meaning that large quantities of air can be stored in a significantly smaller volume. The liquid air is stored is until it is ready for use. Energy is then recaptured by re-vaporizing the liquid air and generating power as the heated air travels through a series of heat exchangers and expanders. The overall system is optimized by taking advantage of waste heat and "waste cold" in the process to reduce the amount of power required to liquefy the air.

LAES is a relatively new application in the energy storage market, however, the major equipment components and technologies used to liquefy, store, and re-vaporize the air have been widely used in many other industry applications for decades. Highview Power is one of the major LAES technology licensors in the market, having completed a LAES pilot plant in Heathrow, UK in 2011. This operational facility uses 350 kW to liquefy the air and provides 2.5 MWh of energy storage.

One of the major similarities between LAES and CAES is that the LAES technology also offers the ability to take advantage of off-peak power to charge the system that can then be later discharged during peak demand hours as described in Section 6.1.

Another similarity LAES shares with adiabatic CAES is a zero emissions process. When coupled with a renewable energy source to provide power for the system, LAES is considered a completely green technology, meaning that it does not have any emissions associated with the process. The system utilizes motor-driven equipment, as opposed to a gas turbine, for the main air compressors and other auxiliary equipment, so there are no emissions generated from combustion. Additionally, there are no hydrocarbons used in the process at all – only air – so fugitive emissions are also non-existent.

The LAES technology can be broken down into three (3) major systems; system charging (air liquefaction), energy storage (liquid air storage), and system discharge (power generation). Each of these systems are relatively independent of one another and therefore can be designed for different amounts of capacity, depending on the specific application and use case. For example, the charging section of the facility (air liquefaction) could be designed to produce liquid air at a rate sufficient enough to utilize any excess energy generated from renewable sources that otherwise would need to be curtailed due to transmission constraints. However, the discharge system could be designed to generate power at the rate required to meet the demand during peak times; this rate may or may not be the same as the charging rate.

The number of hours of available storage can be easily modified by adding additional liquid air storage tanks.

The following sections describe each of these three systems in more detail.

7.1.1 System Charging – Air Liquefaction

Ambient air is used as the source of air for the process. The air is sent through a series of compressors and heat exchangers to increase the pressure from atmospheric to approximately 850 psig. This initial air compression requires the largest amount of power usage for the entire process; there are other users within the process, but they are significantly smaller the main air compressor.

Contaminants in the air such as carbon dioxide, water, and particulates must be removed prior to the liquefaction process. Carbon dioxide and water will freeze at the cryogenic temperatures and could clog the piping, valves, or equipment. The air flows through a set of molecular-sieve beds that adsorb the water and CO₂ from the air – this technology is very similar to the process used in liquefied natural gas (LNG) facilities. Once saturated, the molecular-sieve is regenerated with dry air and ready to be used again.

A common process used to liquefy air is the Claude cycle. In the Claude cycle, the air acts as the process fluid to be cooled as well as the refrigerant. The high pressure air is let-down across an expander and/or valve to low pressure. This rapid reduction in pressure creates a cooling effect, known the Joule-Thompson (JT) effect, and a portion of the air becomes the liquid air product. Any air that is not liquefied is used as a refrigerant to further cool the system and is recycled to go through the process again. This is a well-known and widely industry-recognized process for liquefying air.

7.1.2 Energy Storage – Liquid Air Storage

Once the air is liquefied, it must be stored until ready for use. A benefit that LAES provides over CAES is that a specialized storage site, such as a salt cavern, is not required. Liquid air is stored in field-erected, insulated, cryogenic, storage tanks. These tanks are very similar to the storage tanks used to store other cryogenic liquids (such as liquid nitrogen or liquefied natural gas) and are widely utilized the in the oil, gas, and chemicals industry. By not depending on the geological formations of the site for storage, LAES facilities can be built in any location in which sufficient space is available.

Although the tanks are very well insulated, there will be some amount of the liquid air that "boils-off" as the system sits stagnant. Fortunately, since the contents of the storage system are only air (nitrogen, oxygen, argon, etc.), this "boil-off" vapor can be vented directly to atmosphere with no additional handling equipment required.

Depending on the amount of storage duration desired (i.e. hours of storage), the volume and quantities of storage tanks can be modified. Additional storage duration requires additional storage volume. When determining the size/capacity of the charging system, it is important to consider how long it will take to

fill the storage tanks. If the charging duration is too long, it may be advantageous to increase the charging system capacity.

7.1.3 System Discharge – Power Generation

When ready to use to generate power, the liquid air is pumped from the storage tanks to a heat exchanger in which it is re-vaporized. The warm air then flows through series of heat exchangers and expanders, similar to CAES, in order to generate power via the expander. The rate in which power is generated is determined by the pumping capacity and the expander capacity. The higher discharge rate required, the larger the expander required.

Once the air is fully expanded, it is released back into the atmosphere.

8.0 GRAVITY ENERGY STORAGE

8.1 General Description

Gravity energy storage (GES) offers a technique of storing off peak generation that can be dispatched during peak demand hours. Like Pumped Hydro Storage, GES takes advantage of kinetic and potential energy via mass transfer between different elevations. This developing storage technology presents unique advantages in performance with round-trip efficiencies of approximately 80-90%. GES's largest competing technology is pumped-hydro storage due to similarities in fundamental design. However, GES has little to no site restrictions and can be integrated into any high voltage transmission grid while maintaining an insignificant environmental impact over the storage system's lifespan. Currently, storage capabilities range from 6-14 hours. In addition, gravity storage caries a small land footprint per kWh, thus increasing storage capability per acre.

GES technology is currently in small-scale international operation but is not yet available on a commercial scale. However, due to the growing global demand for large-scale storage options, there is burgeoning interest in the use of GES as a commercial storage solution. CapEx for GES depends on the design of the system and is customizable to balance the economic and performance goals of the project. GES has a large upfront capital cost but does not require as much ongoing CapEx throughout the life of the project due to minimal degradation. The future success of GES systems will depend on their ability to compete with other emerging energy storage methods in the long term.

8.1.1 Vertical Shaft Gravity Energy Storage

Vertical shaft (VS) GES systems consist of a shaft of large diameter, a piston, and other common operational components such as a pump-turbine, generator, etc. The water that fills the large shaft below the piston serves as a medium for energy transfer. The system operates on the simple function of pumping water to hydraulically lift a piston fitted within the large shaft. The steel piston is filled with reinforced rock and concrete materials. A reversible pump-turbine essentially creates a closed-circuit and converts grid power to potential energy by pumping water into the large shaft to raise the piston. During peak demand, the stored potential energy can be converted back into electrical energy by the descending piston that then allows the water under pressure to transfer back through the turbine, and ultimately back onto the grid.

In 2013 a Santa Barbara, California based company, Gravity Power, planned to construct its first commercial GES demonstration in Penzberg, Germany designed with a power shaft depth of 500-m and a 30-m diameter. These parameters produce an equivalence of 160 MWh (40 MW for 4 hours of bulk

energy storage and requires a power consumption of 40 MW for a charge time of approximately 5 hours). This project is expected to have a lifetime of at least 50 years. The total cost estimate of this system was estimated at \$1,100/kWh or \$4,400 kW. Because general planning for a GES can take 2+ years with an additional 3-4 years of construction, this GES project is expected to be operational within the next few years.

8.1.2 Crane-Lift Gravity Energy Storage

A second application of GES employs the elevation of rock or concrete masses by crane to create a tower where potential energy is stored via elevation gain. Electric motors power the lifting of blocks to various levels that then create a tower. The total allowable energy storage is relative to tower height mass of the blocks, and the quantity of the blocks that can fit under the cranes. Energy from the grid is used to lift blocks and during hours of peak demand, energy is returned to the grid when the cranes lower the blocks. The force of gravity pulls the blocks downward, maintaining a constant speed of descent which creates kinetic energy that is converted to electrical energy by turning the electric generator. Since the mass of the blocks affects the CapEx of the cranes, the most cost effective way to increase power and energy capacity for this system is to increase the height of the tower and the velocity at which the blocks descend.

Energy Vault, a Swiss-based company specializing in utility-scale gravity-based energy storage, partnered with Indian energy provider, Tata Power, to deploy a 35-MW system in 2018. Energy Vault has developed a six-arm crane with capability to lift 35T (5,000 concrete blocks) to a height of ~30 stories. The system holds a round-trip efficiency between 80-90%. The storage system's capability maintains ranges of 20-35-80 MWh storage capacity and a 4-8MW of power discharge for 8-16 hours. A 30+ year lifespan is expected for this size GES system. Though this system is small-scale when considering the possible capabilities of its technology, its appeal has propelled Energy Vault and other companies to push the boundaries of crane-lift GES systems. This GES system may be more commonly utilized in the coming years due to large storage capacities, efficiency, low O&M costs, and sparse site restrictions. However, the technology is new, and the concern of its ability to compete with other new storage proposals produced in the long term remains.

8-2

8.1.3 Rail Energy Storage

Rail energy storage (RES) similarly takes advantage of potential energy to store and kinetic energy to discharge energy like Pumped Hydro Storage and the other GES technologies, with a simpler approach and less infrastructure. RES does not require water as a working fluid like pumped hydro and does not involve intensive extraction of materials during the construction process. RES has the potential to have lower CapEx and O&M expenses than other current energy storage options in certain topographical areas. RES storage facilities perform at approximately 80% round-trip operating efficiency while continuously delivering energy for up to 8 hours.

This storage solution utilizes rail cars that haul large masses (typically concrete or rock masses) back and forth between storage yards to store excess energy in times of low demand and easily disperse that energy during peak demand. RES uses surplus electrical energy from nearby renewable plants to power the increase in elevation of rail cars during hours of low demand, which creates potential energy. During hours of peak demand, the rail cars descend back downhill via gravity. This process converts the stored potential energy back into kinetic energy through regenerative braking, a technology commonly seen in electric vehicles. Regenerative braking utilizes the motor as a generator and converts lost kinetic energy from deceleration back into electrical that can be returned to the grid.

In April of 2016, Advanced Rail Energy Storage (ARES), a Santa-Barbara, California based energy startup had its first commercial-scale project approved on behalf of the Bureau of Land Management. The small-scale project, called ARES Nevada, planned for development on ~100 acres of public land near Pahrump, Nevada, has a 50-MW power capacity and can produce 12.5 MWh of energy. The estimated cost of the project is \$55 million (at approximately \$4,400/kWh) with an expected lifespan of 40 years. Though the project was scheduled to be in operation by late 2019 to early 2020, its success is still in question as it has not been in commercial use for an extended period. ARES is currently working on new designs to enable the storage system to perform on much steeper slopes along shorter distances which would allow the technology to be operable in more densely populated regions.

8-1

9.0 BATTERY STORAGE TECHNOLOGY

This Assessment includes standalone battery options for both lithium ion (Li-Ion) and flow battery technologies. Li-Ion options included 1 MW output with 30-minute, 1-hour, 4-hour, and 8-hour storage capacities as well as a 50 MW option with 4-hours of storage. A 1 MW, 1-hour, 4-hour, and 8-hour flow cell battery options were also included, along with a 20MW, 8-hour option. Additionally, the solar and wind summary tables include optional costs for adding Li-Ion battery capacity of 50% of the nominal renewable output to the site with 4-hours of storage.

9.1 General Description

Electrochemical energy storage systems utilize chemical reactions within a battery cell to facilitate electron flow, converting electrical energy to chemical energy when charging and generating an electric current when discharged. Electrochemical technology is continually developing as one of the leading energy storage and load following technologies due to its modularity, ease of installation and operation, and relative design maturity. Development of electrochemical batteries has shifted into three categories, commonly termed "flow," "conventional," and "high temperature" battery designs. Each battery type has unique features yielding specific advantages compared to one another.

9.1.1 Flow Batteries

Vanadium Redox batteries (VRB) and Zinc-Bromide (ZnBr) batteries are representative of commercially available flow battery technologies, but other technologies, such as iron flow batteries, are also available. Generally, flow batteries have lower round-trip efficiencies than Li-Ion batteries, however their theoretical performance does not degrade. This allows flow batteries to exhibit longer life spans than Li-Ion batteries without augmentation.

Developed in the early 1990's by the University of New South Wales in Australia, VRBs employ a two tank, two pump system that contains vanadium-based electrolyte solutions on each side. Electrons are passed between the two solutions via an ion-permeable membrane to charge and discharge the battery. VRBs may be attractive for grid-scale applications due to their long lifetime and potential to scale power and energy capacity independently as needed for a given application. However, commercially available VRBs are generally modular in design, so the electrolyte volumes and discharge durations are limited by the form factor. As products and markets develop further, decoupled designs may arrive with greater design flexibility. The vanadium in the electrolyte does not degrade, so it can be reused/recycled after the useful life of the battery. Zinc-Bromide batteries were developed in the 1970's by Exxon and are often referred to as "hybrid" flow batteries. ZnBr batteries use pumped liquid electrolyte in a single pump, single tank system. During charging, energy is stored by plating electrode surfaces with zinc. Discharging causes the zinc to oxidize and dissolve into the aqueous solution, which releases electrons to do work in the external circuit. The capacity of ZnBr batteries (and other plating style technologies) is dependent on electrode area as well as electrolyte volume. Commercially available units are modular designs with fixed power and energy ratings

9.1.2 Conventional Batteries

A conventional battery contains a cathodic and an anodic electrode and an electrolyte sealed within a cell container that can be connected in series to increase overall facility storage and output. During charging, the electrolyte is ionized such that when discharged, a reduction-oxidation reaction occurs, which forces electrons to migrate from the anode to the cathode thereby generating electric current. Batteries are designated by the electrochemicals utilized within the cell; the most popular conventional batteries are lead acid and Li-Ion type batteries.

Lead acid batteries are the most mature and commercially accessible battery technology, as their design has undergone considerable development since conceptualized in the late 1800s. The Department of Energy (DOE) estimates there is approximately 110 MW of lead acid battery storage currently installed worldwide. Although lead acid batteries require relatively low capital cost, this technology also has inherently high maintenance costs and handling issues associated with toxicity, as well as low energy density (yields higher land and civil work requirements). Lead acid batteries also have a relatively short life cycle at 5 to 10 years, especially when used in high cycling applications.

Li-Ion batteries contain graphite and metal-oxide electrodes and lithium ions dissolved within an organic electrolyte. The movement of lithium ions during cell charge and discharge generates current. Li-Ion technology has seen a resurgence of development in recent years due to its high energy density, low self-discharge, and cycling tolerance. Many Li-Ion manufacturers currently offer 20-year warranties or performance guarantees. Consequently, Li- Ion has gained traction in several markets including the utility and automotive industries.

Li-Ion battery prices are trending downward, and continued development and investment by manufacturers are expected to further reduce production costs. While there is still a wide range of project cost expectations due to market uncertainty, Li-Ion batteries are anticipated to expand their reach in the utility market sector.

9-3

9.1.3 High Temperature Batteries

High temperature batteries operate similarly to conventional batteries, but they utilize molten salt electrodes and carry the added advantage that high temperature operation can yield heat for other applications simultaneously. The technology is considered mature with ongoing commercial development at the grid level. The most popular and technically developed high temperature option is the Sodium Sulfur (NaS) battery. Japan-based NGK Insulators, the largest NaS battery manufacturer, installed a 4 MW system in Presidio, Texas in 2010 following operation of systems totaling more than 160 MW since the project's inception in the 1980s.

The NaS battery is typically a hermetically sealed cell that consists of a molten sulfur electrolyte at the cathode and molten sodium electrolyte at the anode, separated by a Beta-alumina ceramic membrane and enclosed in an aluminum casing. The membrane is selectively permeable only to positive sodium ions, which are created from the oxidation of sodium metal and pass through to combine with sulfur resulting in the formation of sodium polysulfides. As power is supplied to the battery in charging, the sodium ions are dissociated from the polysulfides and forced back through the membrane to re-form elemental sodium. The melting points of sodium and sulfur are approximately 98°C and 113°C, respectively. To maintain the electrolytes in liquid form and for optimal performance, the NaS battery systems are typically operated and stored at around 300°C, which results in a higher self-discharge rate of 14 percent to 18 percent. For this reason, these systems are usually designed for use in high-cycling applications and longer discharge durations.

NaS systems are expected to have an operable life of around 15 years and are one of the most developed chemical energy storage technologies. However, unlike other battery types, costs of NaS systems have historically held, making other options more commercially viable at present.

9.2 Battery Emissions Controls

No emission controls are currently required for battery storage facilities. However, Li-Ion batteries can release large amounts of gas during a fire event. While not currently an issue, there is potential for increased scrutiny as more battery systems are placed into service.

9.3 Battery Storage Performance

This assessment includes performance for multiple Li-Ion options as well as one flow battery option. Li-Ion systems can respond in seconds and exhibit excellent ramp rates and round-trip cycle efficiencies. Because the technology is rapidly advancing, there is uncertainty regarding estimates for cycle life, and these estimates vary greatly depending on the application and depth of discharge. The systems in this Assessment are assumed to perform one full cycle per day, and capacity factors are based on the duration of full discharge for 365 days. OEMs typically have battery products that are designed to suit different use-cases such as high power or high energy applications. The power to energy ratio is commonly shown as a C-ratio (for example, a 1MW / 4 MWh system would use a 0.25C battery product). However, the 8-hour battery option is based on a 0.25C system that is sized for twice the power and discharged for eight hours instead of four. While the technology continues to advance, commercially available, high energy batteries for utility scale applications are generally 0.25C and above.

Flow batteries are a maturing technology that is well suited for longer discharge durations (>4 hours, for example). Flow batteries can provide multiple use cases from the same system and they are not expected to exhibit performance degradation like lithium ion technologies. However, they typically have lower round trip efficiency than Li-Ion batteries. Storage durations are currently limited to commercial offerings from select vendors but are expected to broaden over the next several years. Performance guarantees of 20 years are expected with successful commercialization, but there is not necessarily a technical reason that original equipment manufacturer (OEM) and/or balance of plant (BOP) designs could not accommodate 30+ year life.

9.4 Regulatory Trends

Two (2) Federal Energy Regulatory Commission (FERC) Orders released in 2018 provide clarity on the role of storage in wholesale markets, and potentially drive continued growth. FERC Order 841 requires RTOs and ISOs to develop clear rules regulating the participation of energy storage systems in wholesale energy, capacity, and ancillary services markets. Prior to the final release of FERC 841, the California Public Utilities Commission introduced 11 rules to determine how multi-use storage products participate in California Independent System Operator (CAISO). FERC Order 842 addresses requirements for some generating facilities to provide frequency response, including accommodations for storage technologies. In addition, the Internal Revenue Service (IRS) is considering new guidance for the ITC that will impact projects combining storage with renewables.

Tariffs are a popular concern in the solar and storage market. With recent tariffs, uncertainty of how manufacturing abroad and nationally will be affected has crept into the industry. The "Section 301" tariffs are comprised of four lists of Chinese products that have been selected for tariffs between 15% and 30%. Raw materials used to create Li-Ion batteries and solar modules are already impacted by the Section 301 tariffs in affect and were set to increase from 25% to 30% in late Fall 2020 but has since been delayed. While these tariffs are beginning to increase, manufacturers in China have started to react and move

production of solar and storage products outside of China to Mexico and India to avoid paying some of the tariffs.

9.5 Battery Storage Cost Estimate

The estimated costs of the Li-Ion and flow battery systems are included in the Summary Tables, based on BMcD experience and vendor correspondence. The key cost elements of a Li-Ion battery system are the inverter, the battery cells, the interconnection, and the installation. The capital costs reflect recent trends for overbuild capacity to account for short term degradation. The battery enclosures include space for future augmentation, but the costs associated with augmentation are covered in the O&M costs. It is assumed that land is available at an existing PacifiCorp facility and is therefore excluded from the cost estimate. These options assume the battery interconnects at medium voltage.

Flow battery estimates for the 1 MW options are based on iron flow battery technology. This is a modular design in which the OEM scope includes the tanks, electrolyte storage, and associated pumps and controls in a factory assembled package. The EPC scope includes the inverters, switchgear, MV transformer, and installation.

Demolition costs are meant to reflect the end of life decommissioning efforts. This includes discharging the batteries to the greatest extent possible, shutting the system down, final inspections, and physically disconnecting all electrical equipment. Following this, battery modules will need to be removed from the racks and placed on pallets for shipment to a recycling facility. Lithium-ion batteries are considered Class 9 hazardous waste and is currently treated like e-waste. Once at the recycling facility, a dissembler will break the module down into major subcomponents like steel, cells, copper, printed circuit boards, plastics, etc. The cells are then sent through either a shredding or smelting process to recover valuable metals. Once the cells go through this process, any remaining waste is not considered hazardous. Battery recycling costs vary significant depending on chemistry. Cobalt-based battery chemistries have higher recovery value and because they are more energy dense, typically involve handling less material. In all cases, the cost of disassembly and freight to the recycling facility is estimated to account for 70-90% of the total cost for recycling. Estimates, though, can vary significantly depending on metals pricing and competition in the battery recycling market.

9.6 Battery Storage O&M Cost Estimate

O&M estimates for the Li-Ion and flow battery systems are shown in the Summary Tables, based on BMcD experience and recent market trends. The battery storage system is assumed to be operated remotely.

The technical life of a Li-Ion battery project is expected to be 20 years, but battery performance degrades over time, and this degradation is considered in the system design. Systems can be "overbuilt" by including additional capacity in the initial installation, and they can also be designed for future augmentation. Augmentation means that designs account for the addition of future capacity to maintain guaranteed performance.

Overbuild and augmentation philosophies can vary between projects. Because battery costs are expected to continue falling, many installers/integrators are aiming for lower initial overbuild percentages to reduce initial capital costs, which means guarantees and service contracts will require more future augmentation to maintain capacity. Because costs should be lower in the future, the project economics may favor this approach. This assessment assumes minimal overbuild beyond system efficiency losses, and the O&M estimates include allowances for augmentation.

Battery storage O&M costs are modeled to represent the portions of performance guarantees and augmentation from recent BMcD project experience. The O&M cost for the Li-Ion systems include a nominal fixed cost to administer and maintain the O&M contract with an OEM/integrator, plus an allowance for calendar degradation fees. Calendar degradation represents performance degradation and subsequent augmentation expected to occur regardless of the system's operation profile, even if the batteries sit unused. Because calendar degradation is not tied to system operation or output, it is modeled as part of the fixed O&M.

Previously represented as variable O&M, estimates for Li-ion options account for cycling degradation fees are now also included in the fixed O&M section due to how the industry is now utilizing service agreements. Cycling the batteries increases performance degradation, so the performance guarantees provided by the OEM and/or integrator are commonly modeled to account for augmentation based on the expected operating profile. The augmentation O&M estimates in this assessment are based on an operation profile of one charge/discharge cycle per day and may not be valid for increased cycling.

Flow battery O&M costs are modeled around an annual service contract from the OEM or a factory trained third party. Costs are based on correspondence with manufacturers and are subject to change as the technology achieves greater commercialization and utilization in the utility sector. Unlike Li-Ion technologies, flow batteries generally do not exhibit calendar or cycle degradation, so there is not an augmentation O&M component per cycle. There is mechanical equipment that requires service based on an OEM recommended schedule, which is modeled as a levelized annual cost for the life of the system.

9-7

10.0 CONCLUSIONS

This Renewable Energy Resource Technology Assessment provides information to support PacifiCorp's power supply planning efforts. Information provided in this Assessment is screening level in nature and is intended to highlight indicative, differential costs associated with each technology. BMcD recommends that PacifiCorp use this information to update production cost models for comparison of renewable resource alternatives and their applicability to future resource plans. For specific project development efforts beyond IRP planning, PacifiCorp should pursue additional engineering studies to define project scope, budget, and timeline.

Renewable options include PV and wind systems. PV is a proven technology for daytime peaking power and a viable option to pursue renewable goals. PV capital costs have steadily declined for years, but recent import tariffs on PV panels and foreign steel may impact market trends. Wind energy generation is a proven technology and turbine costs dropped considerably over the past few years.

Utility-scale battery storage systems are being installed in varied applications from frequency response to arbitrage, and recent cost reduction trends are expected to continue. While PHES currently has the most installed capacity for energy storage as a whole, Li-Ion technology is achieving the greatest market penetration in the battery storage sector. This is aided in large part by its dominance in the automotive industry, but other technologies like flow batteries should be monitored, as well.

PacifiCorp's region has several geological sites that can support large scale storage options including PHES and CAES. This gives PacifiCorp flexibility in terms of energy storage. Smaller applications will be much better suited for battery technologies, but if a larger need is identified PHES or CAES could provide excellent larger scale alternatives. Both of these technologies benefit from economies of scale in regard to their total kWh of storage, allowing them to decrease the overall \$/kWh project costs.
APPENDIX A – SUMMARY TABLES

APPENDIX B – SOLAR PVSYST MODEL OUTPUT (5MW)

APPENDIX C – SOLAR OUTPUT SUMMARY

APPENDIX D – WIND PERFORMANCE INFORMATION

APPENDIX E – DECLINING COST CURVES

APPENDIX F – GENERATION CASHFLOWS





CREATE AMAZING.



Burns & McDonnell 9785 Maroon Circle, Suite 400 Centennial, CO 80112 O 303-721-9292 F 303-721-0563 www.burnsmcd.com

ISE PLANT DESCRIPTION minal Output, MW minal Output, MWh pacity Factor (%)	Swan Lake	Goldendale	Saminaa	Badgar Mauntain	Our share																						· · · · · · · · · · · · · · · · · · ·
minal Output, MW minal Output, MWh pacity Factor (%)	400		Semmoe	Bauger Mountain	Owynee	Flat Canyon	Utan PS2	Utah PS3	Banner Mountain					Hydrostor													
minal Output, MWh pacity Factor (%)	400	400	750	500	600	300	500	600	400	150	150	150	300	300	300	500	500	500	1	1	1	1	50	1	1	1 1	20
pacity Factor (%)	3800	3800	7500	4000	4800	1800	4000	4800	3400	600	1200	1800	1200	2400	3600	2000	4000	6000	0.5	1	4	8	200	1	4	8	160
	31%	39%	40%	32%	32%	24%	32%	32%	34%	16%	32%	24%	16%	32%	24%	16%	32%	24%	2%	4%	16%	32%	16%	4%	16%	32%	32%
artup Time (Cold Start), minutes	1.5	1.5	1.8	1.8	1.8	1.8	1.8	1.8	1.5	5	5	5	5	5	5	5	5	5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
I Pumping to Full Gen, minutes	4	4	3.5	3.5	3.5	3.5	3.5	3.5	0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A									
insition Time from Charging to Discharging, minutes	6	6	3.5	3.5	3.5	3.5	3.5	3.5	N/A	10	10	10	10	10	10	10	10	10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
ailability Factor, %	90%	90%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	95%	97%	97%	97%	97%	97%	97%	97%	97%	97%
chnology Rating	Mature	Mature	Mature	Mature	Mature	Mature	Mature	Mature	Mature	Developing	Mature	Mature	Mature	Mature	Mature	Commercial	Commercial	Commercial	Commer								
e Cvcle, vrs	60	60	80	80	80	80	80	80	50+	50+	50+	50+	50+	50+	50+	50+	50+	50+	20	20	20	20	20	20	20	20	20
rmitting & Construction Schedule, year (note 1)	6	10	8	6	8	8	6	8	7	2.5	2.5	2.5	2.5	2.5	3.0	3.0	3.5	3.5	1.5	1.5	1.5	1.5	2	1.5	1.5	1.5	2
			, v	· ·	v		v	· · ·	· ·	2.0	2.0	2.0	2.0	2.0	0.0	0.0	0.0	0.0									
se Load Performance @ (Annual Average)																											
et Plant Output, kW	400 000	400 000	750 000	500.000	600 000	300 000	500.000	600 000	400 000	150 000	150 000	150 000	300.000	300 000	300.000	500 000	500.000	500.000	1 000	1 000	1 000	1 000	50,000	1 000	1 000	1 000	20.000
otal Plant Storage, kW/h (note 2)	3 800 000	4 800 000	7 500 000	4 000 000	4 800 000	1 800 000	4 000 000	4 800 000	3 400 000	600,000	1 200 000	1 800 000	1 200 000	2 400 000	3 600 000	2 000 000	4 000 000	6,000,000	500	1,000	4 000	8,000	200,000	1,000	4 000	8,000	160.00
ime for Full Discharge, hours	9.5	12.0	10	4,000,000	4,000,000	6	4,000,000	4,000,000	8.5	1	8	12	1,200,000	2,400,000	12	2,000,000	4,000,000	12	0.5	1,000	4,000	8	200,000	1,000	4,000	8	100,000
ime for Full Charge, hours	9.5	14.0	10	95	95	72	95	95	10	7	13	20	7	13	20	7	13	20	0.0	12	4.6	9.2	4.6	13	52	10.4	10.4
compression Power, MW (note 11)	N/A	N/Δ	N/A	0.0 Ν/Δ	0.0 N/Δ	N/A	0.0 N/A	N/A	N/A	90	90	90	180	180	180	300	300	300	0.0 N/A	N/A	4.0 N/Δ	0.2 Ν/Δ	4.0 N/Δ	N/A	N/A	N/A	ι N/Δ
cound-Trin Efficiency (%) (note 3)	78%	78%	80%	80%	80%	80%	80%	80%	81%	60%	60%	60%	60%	60%	60%	60%	60%	60%	85%	85%	85%	85%	85%	70%	70%	70%	70%
TIMATED CAPITAL AND O&M COSTS (Note 8)	10%	1070	0070	0070	0070	0070	0070	0070	0170	0070	0070	0070	0070	0070	0070	0070	0070	0070	0070	0070	0070	0070	0070	10%	10/0		
										<u> </u>																	
C Project Capital Costs, 2020 MM\$ (w/o Owner's Costs)	\$814	\$2,146	\$1,625	\$897	\$1,203	\$760	\$1,108	\$1,266	\$900	\$235	\$261	\$290	\$374	\$402	\$439	\$572	\$644	\$700	\$1.1	\$1.2	\$2.2	\$3.5	\$68.0	\$3.6	\$3.9	\$5.9	\$70.0
vner's Costs. 2020 MM\$	\$163	\$429	\$249	\$137	\$184	\$116	\$169	\$194	\$77	\$39	\$46	\$53	\$63	\$73	\$84	\$98	\$118	\$135	\$0.8	\$0.8	\$0.8	\$0.9	\$13.7	\$0.9	\$0.9	\$1.0	\$13.8
Owner's Project Development	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1
Owner's Engineer	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	\$0.1	\$0.1	\$0.1	\$0.1	\$0.2	\$0.1	\$0.1	\$0.1	\$0.2
Owner's Project Management	Included	Included	Included	Included		Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	\$0.1	\$0.1	\$0.1	\$0.1	\$0.2	\$0.1	\$0.1	\$0.1	¢0.2
Owner's Legal Costs	Included	Included	Included	Included		Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	\$0.1	\$0.1	\$0.1	\$0.1	\$0.5	\$0.1	\$0.1	\$0.1	¢0.2
Dermitting and Licensing Fees	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	Included	ቁር) 1	φ0.1 ¢0.1	φ0.1 ¢0.1	\$0.1 \$0.1	φ0.0 ¢0.3	φ0.1 ¢0.1	φ0.1 ¢0.1	\$0.1	ψ0.0 ¢0.3
erninding and Licensing rees	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included	Included in Project	φ0.1	φ0.1	φ0.1	φ0.1	φ0.5	φ0.1	φ0.1	φ0.1	φ0.5								
Generation Switchyard (note 4)	Coste	Costs	Cost	Cost	Cost	Cost	Cost		Included		Cost	\$0.1	\$0.1	\$0.1	\$0.1	\$4.6	\$0.1	\$0.1	\$0.1	\$4.6							
	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project		Included in Project								,									
Fransmission to Interconnection Point (note 4)	Costs	Costs	Cost	Cost	Cost	Cost	Cost	Cost	Included	Cost	N/A	N/A	N/A	N/A	\$3.5	N/A	N/A	N/A	\$3.5								
	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project		Included in Project								,									
fraining/Testing	Costs	Costs	Cost	Cost	Cost	Cost	Cost	Cost	Included in O&M	Cost	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1	\$0.1								
	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project		Included in Project								,									
∠and (note 6)	Costs	Costs	Cost	Cost	Cost	Cost	Cost	Cost	Included	Cost	Assumes Co-located	Assumes Co-located	Assumes Co-located	Assumes Co-located	Assumes Co-located	Assumes Co-located	Assumes Co-located	Assumes Co-located	Assumes Co-								
									Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project	Included in Project								,	
Permanent Plant Equipment and Furnishings	Included	Included	Included	Included	Included	Included	Included	Included	Cost	Cost	Cost	Cost	Cost	Cost	Cost	Cost	Cost	Cost	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Builders Risk Insurance (0.45% of Project Cost)	\$3.7	\$9.7	\$7.3	\$4.0	\$5.4	\$3.4	\$5.0	\$5.7	\$4.1	\$1	\$1	\$1	\$2	\$2	\$2	\$3	\$3	\$3	\$0.00	\$0.01	\$0.01	\$0.02	\$0.31	\$0.02	\$0.02	\$0.03	\$0.32
Owner's Contingency (5% of Total Project Cost)	\$40.9	\$107.8	\$88.9	\$49.0	\$65.8	\$41.5	\$60.6	\$69.2	\$46.3	\$11.8	\$13.1	\$14.6	\$18.8	\$20.2	\$22.0	\$28.7	\$32.3	\$35.2	\$0.1	\$0.1	\$0.1	\$0.2	\$3.9	\$0.2	\$0.2	\$0.3	\$4.0
······································	+					* · · · •								+-+-	+		**==**	· · · · -								,	÷
tal Screening Level Project Costs 2020 MM\$	\$977	\$2 575	\$1 874	\$1 034	\$1,387	\$876	\$1 277	\$1 460	\$977	\$274	\$307	\$343	\$437	\$475	\$523	\$670	\$762	\$835	\$1.9	\$2.0	\$3.0	\$4.4	\$82	\$4	\$5	\$7	\$84
	¢011	<i>4</i> 2 ,010	¥1,014	\$1,004	\$1,001	\$ 010	¥ ., _	¢1,400		v =14	ψ υ υι	V U40	\$101	V +10	4020	\$ 010	\$ 7.02	ŶŨŨŨ	V 1.0	\$ 2.0	\$0.0	v	* * -	¥-1	4 0	ļ <u></u> ,	
C Project Costs 2020 \$/kWh	\$214	\$447	\$217	\$224	\$251	\$422	\$277	\$264	\$265	\$392	\$218	\$161	\$312	\$168	\$122	\$286	\$161	\$117	\$2 200	\$1 200	\$550	\$438	\$340	\$3 600	\$975	\$738	\$438
	V =14	v · · · ·	¥=	v ==-	420 .	**==	v =	¥204	*200	****	\$ 210	¢.c.	** **	\$100	¥.==	*2 00	¢.c.	\$ 111	\$ 2,200	¢1,200	* ****	\$100	\$010	<i>vvvvvvvvvvvvvv</i>	4010	¢,	÷
al Screening Level Project Costs, 2020 \$/kWh	\$257	\$536	\$250	\$259	\$289	\$487	\$319	\$304	\$287	\$457	\$256	\$191	\$364	\$198	\$145	\$335	\$191	\$139	\$3,706	\$1,959	\$753	\$548	\$408	\$4,490	\$1,202	\$864	\$524
molition Costs (end of life cycle) 2020\$/kWh (note 10)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	\$110	\$110	\$110	\$110	\$110	N/A	N/A	N/A	N/A
M Cost 2020 MM\$/vr																											
Fixed O&M Cost 2020 MM\$/vr	¢5	¢15	¢12	¢1/	¢12	\$16	\$1 <i>1</i>	\$12	\$11 /	\$1 Q	¢1 Q	¢1 Q	¢2.8	¢2 8	\$2.8	¢2 2	¢2 2	\$3.3	\$0.04	\$0.05	\$0.07	\$0.10	\$1.38	\$0.013	\$0.013	\$0.027	\$0 G1
Variable O.S.M. Cost, 2020 WIWWW VI	φ0 ¢0	¢10 ¢0	ψι2 ¢0.27	φ1 4 ¢0.97	ψι∠ ¢∩ 27	¢0.07	ψ1 4 ¢Ω 27	¢0.27	ψ11. 4 ¢∩	¢6.50	φ1.3 ¢6 50	ψ1.3 ¢6.50	φ2.0 ¢6.50	φ2.0 ¢6.50	Ψ2.0 ¢6 50	ψ0.0 ¢6 50	ψ0.0 ¢6 50	φ0.0 ¢6 50	wu.u4 Included in EOM		Included in EOM			Included in EOM		Included in EOM	
	φU	φU	φ0.37	φ0.37	φ0.37	φU.37	φυ.37	φυ.37	φU	φ0.50	ΨC.OU	φ0.00	90.0U	φ0.30	φ0.00	φ0.0U	ΦΟ.ΟΟ	φ0.00									
								l	I	<u>IL</u>			<u> </u>		<u> </u>	<u> </u>				I	1	I	1			/	

Note 4. 1MW battery options (Li-lon and Flow) assume interconnection at distribution voltage and therefore excludes GSU and switchyard. Larger options include GSU and switchyard costs as well as a standalone transmission cost. Also assumes to exite is remotely controlled and that batteries cycle once per day. Capital costs assume the system is slightly oversized initially to accommodate normal degradation at the start of the project life, and then degradation supplement cost throughout the project life. O&M accounts for the parasitic power draw of the system, including HVAC and efficiency losses. Note 6. Pumped Hydro O&M excludes major maintenance cost items, like generator rewinds, that are viewed as end of life repairs to extend the intended life of the asset. Note 7. Battery capacity factor and annual O&M is based on one full cycle per day. Note 8. EPC and Owner's Cost estimates exclude AFUDC, Sales Tax, Insurance and Property Tax During Construction Note 9. Compression Capacity Ratio is defined as the relationship of the MWh of generation. Note 9. Demolition costs are not shown for longer life cycle storage options (pumped Hydro, CAES, and flow batteries). Li-lon storage includes the cost to recycle the modules but does not include any resale of raw materials. Note 11. Compressors can be sized to meet most charging duration requirments. A representative size has been chosen for the options shown.

PACIFICORP RENEWABLE TECHNOLOGY ASSESSMENT SU SOLAR GENERATION

PROJECT TYPE

PROJECT LOCATION BASE PLANT DESCRIPTION

Nominal Output, MW

Annualized Energy Production, MWh (Yr 1) AC Capacity Factor at POI (%) (Note 1) Availability Factor, % (Note 2) Assumed Land Use, Acres PV Inverter Loading Ratio (DC/AC)

PV Degradation, %/yr (Note 3)

Technology Rating Permitting & Construction Schedule, year

ESTIMATED PERFORMANCE

Base Load Performance @ (Annual Average) Net Plant Output, kW

ESTIMATED CAPITAL AND O&M COSTS (Note 7)

EPC Project Capital Costs, 2020 MM\$ (w/o Owner's Costs) Modules

Racking w/ Piles Inverter & MV Transformer Labor, Materials, and BOP Equiment Project Indirects, Fee, and Contingency

Owner's Costs, 2020 MM\$

Owner's Project Development Owner's Project Management Owner's Legal Costs Permitting and Licensing Fees Interconnection Switchyard (Note 5) Transmission Interconnection (Note 8) Transmission Interconnection Application and Upgrades (Note Land (Note 4) **Operating Spare Parts** Builders Risk Insurance (0.45% of Project Cost) Owner's Contingency

Total Screening Level Project Costs, 2020 MM\$

EPC Project Costs, 2020 \$/kW Total Screening Level Project Costs, 2020 \$/kW

Demolition Costs (end of life cycle) 2020\$/kW

O&M Cost, 2020 MM\$/yr Third Party LTSA, 2020\$MM/Yr BOP and Other Cost, 2020\$MM/Yr Land Lease Allowance, 2020\$MM/Yr Capital Replacement Allowance, 2020\$/MWh (Notes 3-5) O&M Cost, 2020 \$/kWac-yr

Co-Located Energy Storage - 4 hr Capacity

Add-On Costs Capital Costs, 2020 MM\$ Owner's Costs, 2020 MM\$ Incremental O&M Cost, 2020 MM\$/Yr

Co-Located Energy Storage - 4 hr Capacity + 200MW Wind Add-On Costs

Capital Costs, 2020 MM\$ Owner's Costs, 2020 MM\$ Incremental O&M Cost, 2020 MM\$/Yr

Notes

Note 1. Solar capacity factor accounts for typical losses. 100 and Note 2. Availability estimates are based on vendor correspondence Note 3. PV degradation based on typical warranty information for p Note 4. PV projects assume that land is leased and therefore lanc Note 5. Solar project substation included in EPC cost. Interconnect Note 6. Oregon cost estimates assume union labor. Note 7. EPC and Owner's Cost estimates exclude AFUDC, Sales Note 8. Transmission interconnect allowance assumes 3 miles of Note 9. Transmission interconnect application costs and upgrade costs are representative only. These costs can vary greatly depending on the site location and existing infrastructure.

	Lakevi	ew, OR	Mil	ford, UT
	100 MW	200 MW	100 MW	200 MW
	100	200	100	200
	242,000	484,000	264,900	529,700
	27.6%	27.6%	30.2%	30.2%
	99%	99%	99%	99%
	800	1600	800	1600
	1.30	1.30	1.30	1.30
A 6 b c c c c c c c c c c	1st year: 2%	2nd year: 2%	1st year: 2%	2nd year: 2%
Aπer	Ist Year: 0.5% per year	After 1st Year: 0.5% per year	Aπer 1st Year: 0.5% per year	Aπer 1st Year: 0.5% per
	Mature	Mature	Mature	Mature
	Ζ	Δ	Z	Ζ
	100,000	200,000	100,000	200,000
		I		
	¢113	\$222	¢111	\$216
	\$113 \$18	ΦΖΖΖ ΦΟ1	\$111	\$ 210 \$Q1
	\$40 \$16	φσι \$31	\$40	\$31
	\$4	\$8	\$4	\$8
	\$29	\$59	\$27	\$53
	\$16	\$33	\$16	\$33
	¢71	¢24	¢ 🤈 ۸	¢94
	ማረ ባ \$በ 3	φοι \$0.3	\$24 \$0.3	ዓጋ
	\$0.3 \$0.1	\$0.0	\$0.5	\$0.5
	\$0.3	\$0.3	\$0.3	\$0.3
	\$0.5	\$0.6	\$0.5	\$0.6
	\$2.0	\$2.0	\$2.0	\$2.0
	\$3.5	\$3.5	\$3.5	\$3.5
	\$9.8	\$9.8	\$9.8	\$9.8
	\$0.0	\$0.0	\$0.0	\$0.0
	\$0.8	\$1.6	\$0.8	\$1.6
	\$0.5	\$1.0	\$0.5	\$1.0
	\$6.5	\$12.1	\$6.4	\$11.8
	\$137	\$253	\$135	\$247
	\$1,130 \$4,272	\$1,110	\$1,110	\$1,080
	\$1,372	\$1,200	\$1,351	\$1,234
	\$35	\$35	\$35	\$35
	\$1.7	\$3.2	\$1.9	\$3.5
	\$0.7	\$1.3	\$0.7	\$1.3
	\$0.2	\$0.3	\$0.2	\$0.3
	\$0.4	\$0.8	\$0.6	\$1.1
	\$0.4	\$0.8	\$0.4	\$0.8
	\$16.20	\$16.10	\$17.60	\$17.60
	\$70	\$133	\$68	\$130
	\$6.9	\$10.3	\$6.8	\$10.1
	\$1.38	\$2.57	\$1.38	\$2.57
	N/A	\$365	N/A	\$361
	N/A	\$34	N/A	\$33
	N/A	\$13.37	N/A	\$12.77
/ options have A	C capacity overbuilt for hig	l h voltage losses.	<u> </u>	<u> </u>
dustry publicatio	ons.	and the state of the state		
alline products.	Assuming factory recomme	ended maintenance is performed, I	v performance is estimated to degrad	e ~2% in the first year and 0.5°

PACIFICORP RENEWABLE TECHNOLOGY ASSES WIND GENERATION

PROJECT TYPE

PROJECT LOCATION

BASE PLANT DESCRIPTION

Nominal Output, MW Number of Turbines Capacity Factor (Note 1) Availability Factor, % (Note 2) Assumed Land Use, Acres Technology Rating Permitting & Construction Schedule, year ESTIMATED PERFORMANCE

Base Load Performance @ (Annual Average) Net Plant Output, kW

ESTIMATED CAPITAL AND O&M COSTS (Note 6)

Project Capital Costs, 2020 MM\$ (w/o Owner's Cost

Wind Turbine Generators Roads O&M Building **Collection System** Other BOP, Materials, Labor, Indirects

Owner's Costs, 2020 MM\$

Project Development (Note 3) Wind Resource Assessment Land Control Permitting and Licensing Fees Generation Switchyard Transmission Interconnection (Note 7) Transmission Interconnection Application and Upg Land (Note 4) **Operating Spare Parts** Temporary facilities and Construction Utilities Builders Risk Insurance (0.45% of Project Cost)

Owner's Contingency (5% of Total Project Cost)

Total Screening Level Project Costs, 2020 MM\$

EPC Project Costs, 2020 \$/kW Total Screening Level Project Costs, 2020 \$/kW

Demolition Costs (end of life cycle) 2020\$/kW

O&M Cost, 2020 MM\$/yr O&M Cost, 2020 \$/kW-yr

Co-Located Energy Storage - 4 hr Capacity Add-On Costs Capital Costs, 2020 MM\$

Owner's Costs, 2020 MM\$ Incremental O&M Cost, 2020 MM\$/Yr

<u>Notes</u>

Note 1. Wind capacity factor based on NREL 80 meter w
Note 2. Availability estimates are based on vendor corres
Note 3. Development costs include legal costs, develope
Note 4. Wind projects assume that land is leased and the
Note 5. Oregon and Washington cost estimates assume
Note 6. EPC and Owner's Cost estimates exclude AFUD
Note 7. Transmission interconnect allowance assumes 3
Note 8. Transmission interconnect application and upgra

			Onshore Wind		
	Pocatello, ID	Arlington, OR	Monticello, UT	Medicine Bow, WY	Goldendale, WA
	200 MW				
	200 50 x 4 MW				
	43.0%	43.0%	36.1%	48.6%	43.0%
	95%	95%	95%	95%	95%
	56 Matura	56	56	56	56
	2.5	2.5	2.5	2.5	2.5
				1	
	200,000	200,000	200,000	200,000	200,000
	\$231	\$232	\$231	\$231	\$232
.5)	\$155	\$156	\$155	\$155	\$156
	\$5	\$5	\$5	\$5	\$5
	\$2	\$2	\$2	\$2	\$2
	\$8 \$61	\$8 \$61	\$8 \$61	۵ 8 \$61	\$8 \$61
	\$73	\$73	\$72	\$72	\$73
	\$24.4	\$24.4	\$23.4	\$23.4	\$24.4
	\$1.0	\$1.0	\$1.0	\$1.0	\$1.0
	\$2.4	\$2.4	\$2.4	\$2.4	\$2.4
	\$3.2	\$3.2 \$2.0	\$3.2	\$3.2	\$3.2 ¢2.0
	\$3.5	\$3.5	\$3.5	\$3.5	\$3.5
ades (Note 8)	\$9.8	\$9.8	\$9.8	\$9.8	\$9.8
x ,	\$0.0	\$0.0	\$0.0	\$0.0	\$0.0
	Included in O&M \$12.0	Included in O&M \$12.0	Included in O&M \$12.0	Included in O&M \$12.0	Included in O&N \$12.0
	Included in Project	Included in Project	Included in Project	Included in Project	Included in Proje
	Costs \$14.5	Costs \$14.5	Costs \$14.4	Costs \$14.4	Costs \$14.5
	\$304	\$305	\$303	\$303	\$305
	\$1,155	\$1,160	\$1,155	\$1,155	\$1,160
	\$1,519	\$1,524	\$1,513	\$1,513	\$1,524
	\$13	\$13	\$13	\$13	\$13
	\$10.6	\$10.8	\$10.2	\$9.6	\$10.8
	\$53.0	\$54.0	\$51.0	\$48.0	\$54.0
	\$130	\$133	\$130	\$130	\$133
	\$11.2	\$11.3	\$11.2	\$11.2	\$11.3
	\$2.57	\$2.57	\$2.57	\$2.57	\$2.57

	30/06/20 Page 1/7
: Simulation parameter	S
Coun	ry United States
42.17° N Longitu Time zone UT-8 Altitu 0.20	de -120.40° W de 1441 m
NREL: TMY3 hourly DB (1991-20	005) - TMY
AT	
30/06/20 10h33	
Trackers single array, with ba	cktracking
0° Axis azimu -60° Maximum F Irradiance optimization	th 0° Phi 60°
100Single arr10.00 mCollector wid0.02 mDiagonal	ay lth 4.26 m
+/- 79.9° Ground Cov. Ratio (GC	R) 42.6%
Perez Diffu Circumso	se Imported ar separate
2.4°	
CS3W-400P HE Canadian Solar Inc. 28 modules In paral 13664 Unit Nom. Pow 5466 kWp At operating cor 982 V I m 30186 m ² Cell ar	lel 488 strings rer 400 Wp d. 4961 kWp (50°C) pp 5049 A ea 27114 m²
Solar Ware 840 - PVU-L0840EF	(PRERELEASE)
TMEIC 840 kWac Oper. Volta 4200 kWac Pnom ra 5 units	ge 915-1300 V tio 1.30
4200 kWac Pnom ra	tio 1.30
25.0 W/m²K 3.2 mΩ Loss Fracti Loss Fracti Loss Fracti Loss Fracti Loss Fracti Loss Fracti	on 2.0 % d) 1.2 W/m²K / m/s on 1.5 % at STC on 2.0 % on -0.5 % on 2.0 % at MPP on 0.10 %
	: Simulation parameter Count 42.17° N Longitur Time zone UT-8 Altitur 0.20 NREL: TMY3 hourly DB (1991-20 AT 30/06/20 10h33 Trackers single array, with ba 0° Axis azimu -60° Maximum P Irradiance optimization 100 Single arr 100 Single arr 1000 Collector wid 0.02 m Rig +/- 79.9° Ground Cov. Ratio (GCI Perez Diffu Circumsol 2.4° CS3W-400P HE Canadian Solar Inc. 28 modules In paral 13664 Unit Nom. Pow 5466 kWp At operating con 982 V I m 30186 m ² Cell arr Solar Ware 840 - PVU-L0840ER TMEIC 840 kWac Oper. Voltag 4200 kWac Pnom ration 5 units 4200 kWac Pnom ration 5 units 4200 kWac Pnom ration 5 units 4200 kWac Coss Fraction Loss Fraction Loss Fraction Loss Fraction Loss Fraction Loss Fraction Loss Fraction Loss Fraction

PVSYST 7.0.2							30/06	/20	Page 2/7
	Grid	-Conne	cted Svs	stem: Si	mulation	parame	ters		
Incidence effect (IAI	M): User defir	ned profile				parame			
10°	20°	30°	40°	50°	60°	70°	80°	90°	
1.000	1.000	1.000	0.990	0.990	0.970	0.920	0.760	0.00	0
System loss factor AC wire loss inverte	s er to transfo	Wires	Inverter vol s: 3 x 4000	tage 630 \ mm² 1 m	∕ac tri	Loss Fra	action 0.0	% at S	STC
MV transfo			Grid Vo	Itage 34.5	kV				
Operating losses at	STC I	ron loss (24 Coppe	4/24 Connex er (resistive)	xion) 10.7() loss 3 x 1) kW .03 mΩ	Loss Fra Loss Fra	action 0.2 action 1.4	% at S % at S	TC TC









PVSYST 7.0.2				30/06/20	Page 7/7				
	Grid-	Connected Sy	stem: Loss diagram						
Project :	Pacificor	20-LakeviewOR							
Simulation var	riant : PC20 VC	0 LakeviewOR S	SAT						
Main system na	arameters	System type	- Trackers single array with backtracking						
Horizon		Average Height	2.4°	Januar					
Near Shadings PV Field Orienta PV modules PV Array Inverter Inverter pack User's needs	tion tracking, t	Linear shadings tilted axis, Axis Tilt Model Nb. of modules Solar Ware 840 - PVI Nb. of units Jnlimited load (grid)	0° Axis azimu CS3W-400P HE Pno 13664 Pnom tot U-L0840ER(PRERELEASE) Pno 5.0 Pnom tot	th 0° m 400 Wp al 5466 kV m 840 kW al 4200 kV	Vp ac V ac				
		Loss diagram ov	ver the whole year						
	1704 kWh/m ²	+34.2%	Global horizontal irradiation Global incident in coll. plane						
		9-1.62%	Far Shadings / Horizon						
		9-1.55%	Near Shadings: irradiance loss						
		9-0.99%	IAM factor on global						
		7-2.00%	Soiling loss factor						
	2150 kWh/m ² * 30186 m ² c	oll.	Effective irradiation on collector	rs					
	efficiency at STC = 18.12	.%	PV conversion						
	11755 MWh	7	Array nominal energy (at STC e	ffic.)					
		D -0.50%	PV loss due to irradiance level						
		7-3.63%	PV loss due to temperature						
		+0.50%	Module quality loss						
		9-2.00%	LID - Light induced degradation						
		9-2.10%	Mismatch loss, modules and strings						
		9-1.13%	Ohmic wiring loss						
	10745 MWh	4 000	Array virtual energy at MPP	1					
-		7-1.66%	Inverter Loss during operation (effic	lency)					
		7-2.21%	Inverter Loss over nominal Inv. pow	er					
		90.00%	Inverter Loss over nominal inv. volta	ige					
		9-0.01%	Inverter Loss due to power threshol	d					
		0.00%	Inverter Loss due to voltage thresho	bld					
	10331 MWb	7-0.02%	Night consumption	nut					
	10001 10001		Available Lifergy at inverter Out	put					
		0.00%	AC ohmic loss						
		9-1.78%	Medium voltage transfo loss						
	10146 MWh	70.00%	MV line onmic loss Energy injected into arid						
P	Vs				L				

PVSYST 7.0.2				23/06/20	Page 1/7
Grid-Co	nnected Systen	n: Simulatior	n parameters		
Project : Pacifico	prp20-MilfordUT				
Geographical Site	MilfordUT NSRDB		Country	United	States
Situation	_ Latitude	38.41° N	Lonaitude	-113.02	°W
Time defined as	Time zone UT-7	Altitude	0 m		
Meteo data:	Albedo MilfordUT_NSRDB	0.20 NREL: TMY3 ho	ourly DB (1991-200	5) - TMY	
Simulation variant : Milford	JT SAT	1			
PVS	Simulation date	23/06/20 14h56	KI		
Simulation parameters	System type	Trackers single	e array, with back	tracking	
Tracking plane, tilted axis	Axis Tilt	0°	Axis azimuth	0°	
Rotation Limitations	Minimum Phi Tracking algorithm	-60° Irradiance optim			
Packtracking strategy	Nih of trackers	100	Cingle arrest		
Backtracking strategy	Tracker Spacing	10.00 m	Collector width	4.26 m	
Inactive band	Left	0.02 m	Right	0.02 m	
Backtracking limit angle	Phi limits	+/- 79.9° Groun	d Cov. Ratio (GCR)	42.6%	
Models used	Transposition	Perez	Diffuse Circumsolar	Importe separat	d e
Horizon	Average Height	3.0°			
Near Shadings	Linear shadings				
User's needs :	Unlimited load (grid)				
PV Array Characteristics					
PV module	Si-poly Model	CS3W-400P HE			
Custom parameters definition	Manufacturer	Canadian Solar	Inc.		
Number of PV modules	In series	28 modules	In paralle	488 stri	ngs
Array global power	Nominal (STC)	13664	At operating cond	400 Wp	
Array operating characteristics (50°C)	U mpp	982 V	At operating cond.	5049 A	vp (50 C)
Total area	Module area	30186 m ²	Cell area	27114 r	n²
Inverter	Model	Solar Ware 840	- PVU-L0840ER(F	RERELE	ASE)
Custom parameters definition	Manufacturer	TMEIC	Oper Veltere	015 10	
Inverter pack	Total power	840 KWac 4200 kWac	Oper. Voltage Pnom ratio	1.30	JU V
	Nb. of inverters	5 units	T Hom Fulle	1.00	
Total	Total power	4200 kWac	Pnom ratio	1.30	
PV Array loss factors					
Array Soiling Losses			Loss Fraction	2.0 %	
Thermal Loss factor	Uc (const)	25.0 W/m ² K	Uv (wind)	1.2 W/r	n²K / m/s
Wiring Ohmic Loss	Global array res.	3.2 mΩ	Loss Fraction	1.5 % a	t STC
LID - Light Induced Degradation	1		Loss Fraction	2.0 %	
Module Quality Loss			Loss Fraction	-0.5 %	
Strings Mismatch loss			Loss Fraction	2.0 % a	
unendel 🛛 T), dan Ter (1777 d. d. T. T. T.)					

PVSYST 7.0.2							23/0	6/20	Page 2/7
	Grid	I-Conne	cted Sys	stem: Si	mulation	parame	eters		
Incidence effect	(IAM): User def	ined profile							
10°	20°	30°	40°	50°	60°	70°	80°	90)°
1.000	0 1.000	1.000	0.990	0.990	0.970	0.920	0.760	0.0	000
System loss fac AC wire loss inve	ctors erter to transfo	Wires	Inverter vol s: 3 x 4000	tage 630 ^v mm² 1 m	Vac tri	Loss F	raction 0.	0 % at	STC
MV transfo			Grid Vol	Itage 34.5	kV				
Operating losses at STC Iron loss (24/24 Connexion) 10.73 kW Loss Fraction 0.2 % at STC Copper (resistive) loss 3 x 1.03 mΩ Loss Fraction 1.4 % at STC									









PVSYST 7.0.2			23/06/20	Page 7/7			
	Grid-Connected Sy	stem: Loss diagram					
Project :	Pacificorp20-MilfordUT						
Cimulation variant :							
Simulation variant :	MIITORO I_SAT						
Main system parameters Horizon	System type Average Height	Trackers single array, with backtracking					
Near Shadings PV Field Orientation PV modules PV Array Inverter Inverter pack User's needs	Linear shadings tracking, tilted axis, Axis Tilt Model Nb. of modules Solar Ware 840 - PV Nb. of units Unlimited load (grid)	0° Axis azimut CS3W-400P HE Pnor 13664 Pnom tot U-L0840ER(PRERELEASE) Pnor 5.0 Pnom tot	th 0° m 400 Wp al 5466 k\ m 840 kW al 4200 k\	Vp ac Vac			
	Loss diagram of	ver the whole year					
1903 k	Wh/m ² +33.0%	Global horizontal irradiation Global incident in coll. plane					
	9-1.47%	Far Shadings / Horizon					
	9-1.41%	Near Shadings: irradiance loss					
	9-0.90%	IAM factor on global					
	9-2.00%	Soiling loss factor					
2389 kWh/i	m ² * 30186 m ² coll	Effective irradiation on collector	rs i				
efficiency	at STC = 18 12%	PV conversion					
enciency							
13	3062 MWh	Array nominal energy (at STC en	ffic.)				
	1-4.77%	PV loss due to temperature					
	4-4.1776	Madula quality lass					
	C+0.50%	Module quality loss					
	7-2.00%	LID - Light induced degradation					
	7-2.10%	Mismatch loss, modules and strings					
	9-1.19%	Ohmic wiring loss					
1180	06 MWh	Array virtual energy at MPP					
	7-1.62%	Inverter Loss during operation (effic	iency)				
	7-2.01%	Inverter Loss over nominal Inv. pow	er				
	10.00%	Inverter Loss over nominal inv. volta	de				
	90.00%	Inverter Loss due to power threshol	d				
	70.00%	Inverter Loss due to voltage thresho	bld				
1100	9-0.01%	Night consumption	(recent)				
1130	9 WWW	Available Energy at Inverter Out	put				
	90.00%	AC ohmic loss					
	9-1.73%	Medium voltage transfo loss					
1.000	90.00%	MV line ohmic loss					
1111	3 MWh	Energy injected into grid					
P	3 MWh	MV line ohmic loss Energy injected into grid					



Burns & McDonnell, Energy Division

Project Name:

Pacificorp 2020 Renewables Technology Assessment

Date:

Variant:

VC0

26-Jun-20

Site Information						
City / State:	Lakeview, OR					
Latitude (N):	42.17 °					
Longitude (W):	-120.4 °					
Altitude	1441 m					
ASHRAE Cooling DB Temp.	32.2 °C					
ASHRAE Extreme Mean Min. Temp.	-22.6 °C					

Design Parameters							
System DC Voltage	1500 VDC						
GCR	42.6 %						
Row spacing	10 m						
Mounting	Tracker						
Tilt angle or rotation limits	60 °						
Azimuth	0 °						
Tracking strategy	TRUE						
Availability	100.0 %						
Degradation	0.5 %/yr						

Array Level Information	
Module rating	400 W
# Modules per string	28
Strings in parallel	488
Total number of modules	13664
DC capacity	5466 kW
Inverter rating	4200 kW
DC/AC ratio - Inv Rating	1.301

PVsyst Input Parameters	
Transposition model	Perez
Constant thermal loss factor (Uc)	25.0 W/m2-K
Wind loss factor (Uv)	1.2 W/m2-K/m/s
Soiling losses	2.2 %
Light induced degradation	2.0 %
DC wiring loss	1.5 %
Module quality loss	-0.4 %
Module mismatch loss	1.0 %
DC health loss	1.0 %

Estimated Annual Energy Production	
P50 net production (yr-1)	241986.6 MWh
AC capacity factor - Inv Rating	27.62%
AC capacity factor - POI Rating	27.62%
DC capacity factor	21.23%
Specific Production	1860 kWh/kWp/yr
Performance Ratio PR	81.15%
Night time losses	-407.2 MWh
Plant Output Limitations	0.00%

Facility Level Information	
Nameplate Capacity	130.13 MWDC
Number of modules	325333
Nameplate Capacity	100.00 MWAC
Number of arrays	24
Interconnection Limit	100.00 MWAC
Inteconnection Voltage	34.5 kV
DC/AC ratio - POI Rating	1.301

Weather		
Source	TMY3	
GHI	1704.3 kWh/m2	
DHI	kWh/m2	
Global POA	2287.5 kWh/m2	
Average Temp.	7.87 °C	
Average Temp. (Generation)	12.45 °C	
Average Wind	3.33 m/s	
Average Wind (Generation)	3.61 m/s	

AC System Losses		
MV transformer no-load losses	0.00%	
MV transformer full load losses	0.00%	
MV collection system	1.30%	
HV transformer no-load losses	0.07%	
HV transformer full load losses	0.48%	
HV line	0.05%	
Auxiliary	0.01%	



Burns & McDonnell, Energy Division

Project Name:

Pacificorp 2020 Renewables Technology Assessment

Date:

Variant:

VC0

26-Jun-20

Site Information	
City / State:	Lakeview, OR
Latitude (N):	42.17 °
Longitude (W):	-120.4 °
Altitude	1441 m
ASHRAE Cooling DB Temp.	32.2 °C
ASHRAE Extreme Mean Min. Temp.	-22.6 °C

Design Parameters	
System DC Voltage	1500 VDC
GCR	42.6 %
Row spacing	10 m
Mounting	Tracker
Tilt angle or rotation limits	60 °
Azimuth	0 °
Tracking strategy	TRUE
Availability	100.0 %
Degradation	0.5 %/yr

Array Level Information		
Module rating	400 W	
# Modules per string	28	
Strings in parallel	488	
Total number of modules	13664	
DC capacity	5466 kW	
Inverter rating	4200 kW	
DC/AC ratio - Inv Rating	1.301	

PVsyst Input Parameters		
Transposition model	Perez	
Constant thermal loss factor (Uc)	25.0 W/m2-K	
Wind loss factor (Uv)	1.2 W/m2-K/m/s	
Soiling losses	2.2 %	
Light induced degradation	2.0 %	
DC wiring loss	1.5 %	
Module quality loss	-0.4 %	
Module mismatch loss	1.0 %	
DC health loss	1.0 %	

Estimated Annual Energy Production	
P50 net production (yr-1)	483973.1 MWh
AC capacity factor - Inv Rating	27.62%
AC capacity factor - POI Rating	27.62%
DC capacity factor	21.23%
Specific Production	1860 kWh/kWp/yr
Performance Ratio PR	81.15%
Night time losses	-814.4 MWh
Plant Output Limitations	0.00%

Facility Level Information	
Nameplate Capacity	260.27 MWDC
Number of modules	650667
Nameplate Capacity	200.00 MWAC
Number of arrays	48
Interconnection Limit	200.00 MWAC
Inteconnection Voltage	34.5 kV
DC/AC ratio - POI Rating	1.301

Weather		
Source	TMY3	
GHI	1704.3 kWh/m2	
DHI	kWh/m2	
Global POA	2287.5 kWh/m2	
Average Temp.	7.87 °C	
Average Temp. (Generation)	12.45 °C	
Average Wind	3.33 m/s	
Average Wind (Generation)	3.61 m/s	

AC System Losses		
MV transformer no-load losses	0.00%	
MV transformer full load losses	0.00%	
MV collection system	1.30%	
HV transformer no-load losses	0.07%	
HV transformer full load losses	0.48%	
HV line	0.05%	
Auxiliary	0.01%	



Project Name:

Burns & McDonnell, Energy Division Pacificorp 2020 Renewables Technology Assessment

Date:

Variant:

26-Jun-20

Site Information	
City / State:	Milford, UT
Latitude (N):	38.41 °
Longitude (W):	-113.02 °
Altitude	<mark>0</mark> m
ASHRAE Ext. Max Mean Temp	38.1 °C
ASHRAE 99.6% Heating DB	-19.8 °C

VC0

Design Parameters		
System DC Voltage	1500 VDC	
GCR	42.6 %	
Row spacing	10 m	
Mounting	Tracker	
Tilt angle or rotation limits	60 °	
Azimuth	0 °	
Tracking strategy	TRUE	
Availability	100.0 %	
Degradation	0.5 %/vr	

Array Level Information	
Module rating	400 W
# Modules per string	28
Strings in parallel	488
Total number of modules	13664
DC capacity	5466 kW
Inverter Rating	4200 kW
DC/AC ratio - Inv Rating	1.301

PVsyst Input Parameters	
Transposition model	Perez
Constant thermal loss factor (Uc)	25.0 W/m2-K
Wind loss factor (Uv)	1.2 W/m2-K/m/s
Soiling losses*	2.0 %
Light induced degradation	2.0 %
DC wiring loss	1.5 %
Module quality loss	-0.5 %
Module mismatch loss	1.0 %
DC health loss	1.0 %
Albedo*	1.0 %

Estimated Annual Energy Production	
P50 net production (yr-1)	264852.0 MWh
AC capacity factor - Inv Rating	30.23%
AC capacity factor - POI Rating	30.23%
DC capacity factor	23.23%
Specific Production	2035 kWh/kWp/yr
Performance Ratio PR	80.39%
Night time losses	-398.3 MWh
Plant Output Limitations	0.00%

Facility Level Information		
Nameplate Capacity	130.13 MWDC	
Number of modules	325333	
Nameplate Capacity	100.00 MWAC	
Number of arrays	24	
Interconnection Limit	100.00 MWAC	
Inteconnection Voltage	34.5 kV	
DC/AC ratio - POI Rating	1.301	

Weather	
Source	TMY3
GHI	1903.4 kWh/m2
DHI	kWh/m2
Global POA	2531.7 kWh/m2
Average Temp.	9.92 °C
Average Temp. (Generation)	14.87 °C
Average Wind	2.11 m/s
Average Wind (Generation)	2.81 m/s

AC System Losses	
MV transformer no-load losses	0.00%
MV transformer full load losses	0.00%
MV collection system	1.30%
HV transformer no-load losses	0.07%
HV transformer full load losses	0.48%
HV line	0.05%
Auxiliary	0.01%



Project Name:

Burns & McDonnell, Energy Division Pacificorp 2020 Renewables Technology Assessment

Date:

Variant:

26-Jun-20

Site Information	
City / State:	Milford, UT
Latitude (N):	38.41 °
Longitude (W):	-113.02 °
Altitude	0 m
ASHRAE Ext. Max Mean Temp	38.1 °C
ASHRAE 99.6% Heating DB	-19.8 °C

VC0

Design Parameters	
System DC Voltage 1500 VDC	
GCR	42.6 %
Row spacing	10 m
Mounting	Tracker
Tilt angle or rotation limits	60 °
Azimuth	0 °
Tracking strategy	TRUE
Availability	100.0 %
Degradation	0.5 %/yr

Array Level Information								
Module rating	400 W							
# Modules per string	28							
Strings in parallel	488							
Total number of modules	13664							
DC capacity	5466 kW							
Inverter Rating (Max Temp & 95% pf)	4200 kW							
DC/AC ratio - Inv Rating	1.301							

PVsyst Input Parameters								
Transposition model	Perez							
Constant thermal loss factor (Uc)	25.0 W/m2-K							
Wind loss factor (Uv)	1.2 W/m2-K/m/s							
Soiling losses*	2.0 %							
Light induced degradation	2.0 %							
DC wiring loss	1.5 %							
Module quality loss	-0.5 %							
Module mismatch loss	1.0 %							
DC health loss	1.0 %							
Albedo*	1.0 %							

Estimated Annual Energy Production								
P50 net production (yr-1)	529704.0 MWh							
AC capacity factor - Inv Rating	30.23%							
AC capacity factor - POI Rating	30.23%							
DC capacity factor	23.23%							
Specific Production	2035 kWh/kWp/yr							
Performance Ratio PR	80.39%							
Night time losses	-796.6 MWh							
Plant Output Limitations	0.00%							

Facility Level Information								
Nameplate Capacity	260.27 MWDC							
Number of modules	650667							
Nameplate Capacity	200.00 MWAC							
Number of arrays	48							
Interconnection Limit	200.00 MWAC							
Inteconnection Voltage	230 kV							
DC/AC ratio - POI Rating	1.301							

Weather							
Source	TMY3						
GHI	1903.4 kWh/m2						
DHI	kWh/m2						
Global POA	2531.7 kWh/m2						
Average Temp.	9.92 °C						
Average Temp. (Generation)	14.87 °C						
Average Wind	2.11 m/s						
Average Wind (Generation)	2.81 m/s						

AC System Losses							
MV transformer no-load losses	0.00%						
MV transformer full load losses	0.00%						
MV collection system	1.30%						
HV transformer no-load losses	0.07%						
HV transformer full load losses	0.48%						
HV line	0.05%						
Auxiliary	0.01%						













COPYRIGHT © 2018 BURNS & McDONNELL ENGINEERING COMPANY, INC.



Notes:

1. The declining cost curve for onshore wind was developed using NREL Land-Based Wind Classes (Class) moderate overnight cost inforamtion. The costs for Class 2, Class 6, and Class 8 were averaged to represent the Pacificorp identified sites based on average wind speed.

2. The declining cost curve for utility solar photovoltaic was developed using NREL mid overnight cost inforamtion.

3. The declining cost curve for battery storage was developed using NREL mid overnight CAPEX cost information for a storage device with 15-year life and 85% round-trip efficiency for 4- hour storage.

Overnight Cost Forecast (\$/kW)												
Те	chnology	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030
Wind		\$1,684.96	\$1,664.76	\$1,643.66	\$1,621.65	\$1,598.74	\$1,574.92	\$1,550.20	\$1,524.58	\$1,498.05	\$1,470.62	\$1,442.28
	Percentage of 2020	100.00%	98.80%	97.55%	96.24%	94.88%	93.47%	92.00%	90.48%	88.91%	87.28%	85.60%
Solar		\$1,324.76	\$1,274.15	\$1,223.53	\$1,172.91	\$1,122.30	\$1,071.68	\$1,021.06	\$970.45	\$919.83	\$869.22	\$818.60
	Percentage of 2020	100.00%	96.18%	92.36%	88.54%	84.72%	80.90%	77.08%	73.25%	69.43%	65.61%	61.79%
Storage (\$/	/kWh)	\$370.00	\$351.00	\$331.00	\$312.00	\$293.00	\$273.00	\$260.00	\$247.00	\$234.00	\$221.00	\$208.00
	Percentage of 2020	100.00%	94.86%	89.46%	84.32%	79.19%	73.78%	70.27%	66.76%	63.24%	59.73%	56.22%






25 - Year Cashflows

200	MW	UT	So	lar
-----	----	----	----	-----

Year:	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
Capital Cost, \$MM:	\$ 216.00	\$-	\$-	\$ -	\$-	\$ -	\$ -	\$-	\$ -	\$ -	\$ -	\$-	\$ -	\$-	\$ -	\$ 11.59	\$ -	\$ -	\$ -	\$-	\$-	\$ -	\$-	\$ -	\$ -	\$ -
0&M, \$MM:	\$-	\$ 3.59	\$ 3.68	\$ 3.77	\$ 3.86	\$ 3.96	\$ 4.06	\$ 4.16	\$ 4.26	\$ 4.37	\$ 4.48	\$ 4.59	\$ 4.71	\$ 4.82	\$ 4.95	\$ 5.07	\$ 5.20	\$ 5.33	\$ 5.46	\$ 5.60	\$ 5.74	\$ 5.88	\$ 6.03	\$ 6.18	\$ 6.33	\$ 6.49
200 MW UT Wind																										
Year:	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25

reur.	•	-	-			~	•		•	~																23
Capital Cost, \$MM:	\$ 231.00	\$ -	\$-	\$ 0.44	\$ 0.45	\$ 0.46	\$ 0.89	\$ 0.91	\$ 0.93	\$ 0.96	\$ 0.98	\$ 1.67	\$ 1.72	\$ 1.76	\$ 1.80	\$ 1.85	\$ 1.89	\$ 1.94	\$ 1.99	\$ 2.04	\$ 2.09	\$ 3.00	\$ 3.07	\$ 3.15	\$ 3.23	\$ 3.31
0&M, \$MM:	\$ -	\$10.46	\$10.72	\$10.98	\$11.26	\$11.54	\$11.83	\$12.12	\$12.43	\$12.74	\$13.06	\$13.38	\$13.72	\$14.06	\$14.41	\$14.77	\$15.14	\$ 15.52	\$ 15.91	\$16.31	\$16.71	\$17.13	\$17.56	\$ 18.00	\$18.45	\$18.91

50 MW 200 MWh Storage

Year:	0		1		2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
Capital Cost, \$MM:	\$	68.00	\$	-	\$ -	\$-	\$-	\$-	\$-	\$ -	\$ -	\$-	\$ -	\$ -	\$-	\$ -	\$ -	\$ 4.71	\$ -	\$ -	\$ -	\$ -	\$ -
0&M, \$MM:	\$	-	\$	1.41	\$ 1.45	\$ 1.49	\$ 1.52	\$ 1.56	\$ 1.60	\$ 1.64	\$ 1.68	\$ 1.72	\$ 1.77	\$ 1.81	\$ 1.86	\$ 1.90	\$ 1.95	\$ 2.00	\$ 2.05	\$ 2.10	\$ 2.15	\$ 2.21	\$ 2.26