DRY CANYON PUMPED STORAGE HYDROPOWER PROJECT

APPLICATION FOR PRELIMINARY PERMIT

INITIAL STATEMENT, GENERAL CONTENT, AND EXHIBITS 1 THROUGH 3



October 2021

TABLE OF CONTENTS

Acronyms	iii
Initial Statement	1
General Content	4
Exhibit 1 - Project Description	7
 1.1 General Project Configuration. 1.1.1 Dam and Levee. 1.1.2 Spillways	7 7 7 7 7
1.2 Proposed Reservoirs 1.2.1 Lower Reservoir 1.2.2 Upper Reservoir	7 7 8
1.3 Transmission Lines	8
1.4 Average Annual Energy Production and Installed Capacity	8
 1.5 Lands of the United States. 1.5.1 U.S. Bureau of Land Management. 1.5.2 U.S. Fish and Wildlife Service	9 9 9 9 9
1.6 Public Interest	9
Exhibit 2 - Description of Studies	. 11
2.1 Study Process 2.1.1 Cultural Resource Study	11 11 11 12 12 12 12 12 13 13 13 13
2.2 Work Plan for New Dam Construction	13
2.3 Waiver	14
2.4 Costs and Financing 2.4.1 Estimated Costs 2.4.2 Financial Sources	14 14 14

 2.5 Schedule for Studies
 2.6 References
 Exhibit 3 - Project Maps

LIST OF FIGURES

EXHIBIT 3 - PROJECT MAPS

SHEET 1 – DRY CANYON PUMPED STORAGE HYDROPOWER PROJECT, OVERVIEW MAP

- SHEET 2 DRY CANYON PUMPED STORAGE HYDROPOWER PROJECT, PRELIMINARY PERMIT BOUNDARY MAP
- SHEET 3 DRY CANYON PUMPED STORAGE HYDROPOWER PROJECT, DETAIL MAP

LIST OF APPENDICES

APPENDIX A - FERC FORM 587 Appendix B - Listing of Lands of the United States

ACRONYMS AND ABBREVIATIONS

Application	Application for Preliminary Permit
CFR	Code of Federal Regulations
FERC	Federal Energy Regulatory Commission
FPA	Federal Power Act
kV	Kilovolt
MW	Megawatt
MWh	Megawatt-hour
NAVD88	North American Vertical Datum of 1988
TWh	Terawatt-hour
USFWS	U.S. Fish and Wildlife Service

INITIAL STATEMENT¹

BEFORE THE FEDERAL ENERGY REGULATORY COMMISSION

APPLICATION FOR PRELIMINARY PERMIT

- (1) PacifiCorp (Applicant) applies to the Federal Energy Regulatory Commission (FERC) for a preliminary permit for the proposed Dry Canyon Pumped Storage Hydropower Project (Project), as described in the attached exhibits. This Application is made in order that the Applicant may secure and maintain priority of Application for a license for the Project under Part I of the Federal Power Act (FPA) while obtaining the data and performing the acts required to determine the feasibility of the Project and to support an Application for a license.
- (2) The location of the proposed Project is:

State or territory: Idaho County: Bear Lake County Township or nearby town: Saint Charles Stream or other body of water: Mud Lake (A part of the Applicant's Bear River water storage and delivery system.)

(3) The exact name and business address of the Applicant are:

PacifiCorp 825 NE Multnomah, Suite 2000 Portland, OR 97232

The exact name and business address of each person authorized to act as agent for the Applicant in this Application are:

Mark Stenberg, License Program Manager PacifiCorp 822 Grace Power Plant Rd. Grace, ID 83241 Email: Mark.Stenberg@PacifiCorp.com Phone: (208) 339-9552

Tim Hemstreet, Managing Director, Renewable Energy Development PacifiCorp 825 NE Multnomah, Suite 1800 Portland, OR 97232 Email: Tim.Hemstreet@pacificorp.com Phone: (503) 813-6170

¹ 18 Code of Federal Regulations (CFR) §4.81(a)

Dustin Till, Assistant General Counsel PacifiCorp 825 NE Multnomah, Suite 2000 Portland, OR 97232 Email: Dustin.Till@pacificorp.com Phone: (503) 813-6589

- (4) The Applicant, PacifiCorp, is a domestic corporation and is not claiming municipal preference under section 7(a) of the FPA. PacifiCorp, a corporation located in Portland, Oregon, is organized under the laws of the State of Oregon and, as such, is qualified under § 4(e) of the FPA to hold hydroelectric licenses issued under Part I of the FPA.
- (5) The proposed term of the requested permit is 48 months.
- (6) The proposed project would use the existing facilities and rights, as follows:

PacifiCorp Facilities Background

The Applicant owns and operates the over 100-year-old Bear Lake Facilities. These existing facilities are used by the Applicant to divert water from the Bear River and to store and release water from the Bear Lake Reservoir (Bear Lake and Mud Lake). The Bear Lake Facilities include Stewart Dam, Rainbow Canal Headgates, Rainbow Canal, Ream-Crocket Canal Intake, Ream-Crocket Canal, Bear Lake Causeway Inlet, Lifton Pumping Station, Outlet Canal, Paris Dike and Outlet Canal Headgates. The Bear Lake Facilities were in place and functioning in 1914 except for the Lifton Pumping Station, which became operational in 1917. In addition to irrigation water storage and delivery, this system allows the management of Bear River water for flood control and power generation.

Prior to the construction of these facilities, a right-of-way over the Bear Lake Reservoir (Mud Lake and Bear Lake) for the storage and conveyance of water was granted by the Secretary of the Interior in 1907. In 1927, the portion of the 1907 right-of-way north of Paris Dike was reduced in size to only cover Outlet Canal. The current footprint of the Mud Lake portion of the right-of-way is 15,487 acres.

Within Mud Lake is the Mud Lake Regulation Reservoir, created by the facilities mentioned above and habitat management dikes built by the U.S. Fish and Wildlife Service (USFWS) as part of its management of the Bear Lake National Wildlife Refuge. The Mud Lake Regulation Reservoir occupies approximately 8,286 acres (in normal operation) within the larger Mud Lake area. During periods of high runoff, the water control structures in the habitat management dikes are opened to allow the full water storage capability of the 15,487 acres of Mud Lake to be used. Normal maximum full pool of the Mud Lake Regulation Reservoir is 5,930.78 feet NAVD88 (maximum flood full pool is 5,931.78 NAVD88).

At the upstream end of this system, water is diverted from the Bear River at Stewart Dam and then conveyed through the Rainbow Canal Headgate and Rainbow Canal to the Mud Lake Regulation Reservoir. Once in the Mud Lake Regulation Reservoir water can be stored, diverted back to the Bear River through Outlet Canal, or moved into Bear Lake through the Bear Lake Causeway Inlet.

The Applicant currently holds water rights from the states of Idaho and Utah to divert the Bear River at Stewart Dam and store diverted Bear River water in the Bear Lake Reservoir. The Applicant has a right to use the stored water for irrigation, power generation, and other beneficial purposes recognized by law.

In addition to the existing Bear Lake Facilities, right-of-way, and water rights, there are three existing 345-kilovolt (kV) transmission lines located within 20 miles of the proposed Project that could be used to support transmission needs. The Applicant's proposed 500-kV line (Gateway West) is near these corridors also.

Existing Facilities to be Utilized

The water for the Project will be diverted at Stewart Dam and conveyed through Rainbow Canal to Mud Lake Regulation Reservoir using existing facilities, water rights and storage rights. The Applicant is proposing to use a portion of the Mud Lake Regulation Reservoir along with associated facilities and rights for development of a lower reservoir for the Project. The Applicant is the sole owner of these existing facilities and rights

GENERAL CONTENT²

(1) Identify every person, citizen, association of citizens, domestic corporation, municipality, or state that has or intends to obtain and will maintain any proprietary right necessary to construct, operate, or maintain the Project:

PacifiCorp 825 NE Multnomah, Suite 2000 Portland, OR 97232

- (2) *Identify (providing names and mailing addresses):*
 - (i) *Every county in which any part of the Project, and any Federal facilities that would be used by the Project, would be located:*

Bear Lake County Cindy Garner, County Clerk 30 N. Main, P.O. Box 190 Paris, ID 83261

The lower reservoir and intake/outtake structure would be located within the federal boundary of the Bear Lake National Wildlife Refuge, in Bear Lake County.

- (ii) Every city, town, or similar local political subdivision:
 - (A) *In which any part of the Project, and any Federal facilities that would be used by the Project, would be located:*

The Project would not be located within any city, town, or similar local political subdivision.

(B) *That has a population of 5,000 or more people and is located within 15 miles of the Project dam:*

There are no cities, towns, or similar local political subdivisions with a population of 5,000 or more people within 15 miles of the Project dams.

- (iii) Every irrigation district, drainage district, or similar special purpose political subdivision:
 - (A) *In which any part of the Project, and any Federal facilities that would be used by the Project, would be located:*

The Project is in Water District 11, Bear River, an organized government entity created and supervised by the Idaho Department of Water Resources to distribute water consistent with water rights on record.

² 18 CFR §4.32(a)

The Bear Lake National Wildlife Refuge is within Water District 11, Bear River. The Project's lower reservoir and intake/outlet structure would be located within the federal boundary of the Bear Lake National Wildlife Refuge.

There are no other irrigation districts, drainage districts, or similar special purpose political subdivisions in which any part of the Project or any other federal facilities used by the Project would be located.

(B) *That owns, operates, maintains, or uses any Project facilities or any Federal facilities that would be used by the Project:*

There are no irrigation districts, drainage districts, or similar special purpose political subdivisions that own, operate, maintain, or use any Project facilities or federal facilities that would be used by the Project.

(iv) Every other political subdivision in the general area of the Project that there is reason to believe would likely be interested in, or affected by, the Application:

Bear Lake County, Idaho, would likely be interested in the Project. The Project has the potential to create economic benefits in Bear Lake County.

(v) All Indian tribes that may be affected by the Project:

Northwestern Band of the Shoshone Nation Brigham City Office 707 North Main Street Brigham City, Utah 84302

Shoshone Bannock Tribes P.O. Box 306 Pima Drive, Fort Hall, ID 83203

Ute Indian Tribe of the Uintah and Ouray Reservation P.O. Box 190 Fort Duchesne, Utah 84026-0190

UNITED STATES OF AMERICA BEFORE THE FEDERAL ENERGY REGULATORY COMMISSION

))

)

PacifiCorp

Dry Canyon Pumped Storage Hydropower Project

Project No.

SUBSCRIPTION AND VERIFICATION

In witness whereof Applicant PacifiCorp has caused its name to be hereunto executed by Tim Hemstreet, PacifiCorp, Managing Director, Renewable Energy Development, this 8⁻¹⁴ day of October 2021.

State of Oregon County of Multnomah

PACIFICORP

by: Tim Hemstreet, Managing Director, Renewable Energy Development PacifiCorp 825 NE Multnomah, Suite 1800 Portland, OR 97232

being duly sworn, deposes and says that the contents of this Application for Preliminary Permit for the Dry Canyon Pumped Storage Hydropower Project are true to the best of his knowledge or belief. The undersigned Applicant has signed the Application this $\underline{\mathcal{B}}^{\mathcal{H}}$ day of October 2021.

Tim Hemstreet, PacifiCorp, Managing Director, Renewable Energy Development

Subscribed and sworn to before me, a Notary Public of the State of Oregon this 2th day of October 2021.

Kelly A. Wiggins, Notary Public

My Commission Expires 10 26 20 21



EXHIBIT 1 - PROJECT DESCRIPTION

1.1 General Project Configuration

The proposed Dry Canyon Pumped Storage Hydropower Project (Project) is a closed-loop pumped storage hydroelectric generating facility.

1.1.1 Dam and Levee

7,900 feet!

A roller-compacted concrete dam with a height of 530 feet and a crest length of 2,900 feet would create the upper reservoir in Dry Canyon. Dam Crest would be at approximately 7,437 feet NAVD88.

A rock-armored earthen levee with an average height of 22 feet above the bottom of the Mud Lake Regulation Reservoir and a length of 24,242 feet would be constructed to form the lower reservoir. Two inlet/outlet structures would be included, one each in the north and west levees. The top of the levee would be approximately 5,942 feet NAVD88.

1.1.2 Spillways

The need for an upper reservoir auxiliary spillway will be analyzed during engineering studies proposed under Section 2.1.3.

1.1.3 Penstocks

Starting at the upper reservoir's inlet/outlet structure behind the dam, three 22-foot-diameter penstocks, each being approximately 6,650 feet in length, would connect to the generating/pumping units in the underground chamber. A combination of exposed penstocks, concrete-lined tunnels and steel-lined tunnels are proposed.

1.1.4 Underground Generating/Pumping Station

Proposed dimensions of the underground generating/pumping station chamber are 660 feet long and 110 feet wide. An access tunnel and a utility tunnel are proposed to provide access to the underground chamber. The access tunnel would provide primary operations access from Merkley Road and the upper utility tunnel would connect to the switch yard.

1.1.5 Tailraces

Below the generating/pumping units, three 22-foot diameter concrete-lined tailrace tunnels would connect to the inlet/outlet structure in the lower reservoir. The proposed tailrace tunnels would each be approximately 2,200 feet in length.

1.2 Proposed Reservoirs

1.2.1 Lower Reservoir

A lower reservoir with a surface area of 1,390 acres is proposed to be sited in the southeast corner of the 8,286-acre Mud Lake Regulation Reservoir. The lower reservoir would have a storage volume of 30,680 acre-feet (23,730 active and 4,170 dead pool). Reservoir full-pool surface elevation is proposed to be approximately 5,938.88 feet NAVD88. The reservoir would

have two feet of free board above full pool. The 24,242 feet of levee and natural landforms would form this reservoir and separate it from the waters of Mud Lake Regulation Reservoir to create a closed-loop system. See Section 6 of the Initial Statement of this Application for a description of the Applicant's facilities that comprise the Mud Lake Regulation Reservoir. Other alternatives to use the Mud Lake Regulation Reservoir for a lower pumped storage reservoir may be investigated.

1.2.2 Upper Reservoir

An upper reservoir with a surface area of 182 acres is proposed to be sited east of Mud Lake in Dry Canyon. The upper reservoir would have a storage volume of approximately 26,880 acrefeet (23,730 active and 3,150 dead pool). Reservoir full-pool surface elevation is proposed to be approximately 7,426.88 feet NAVD88. The reservoir would have ten feet of freeboard above full pool. The upper reservoir would include an inlet/outlet structure connected to the dam and penstocks. The need for an auxiliary spillway will be evaluated.

1.3 Transmission Lines

The Project would require construction of an up to 500 kV transmission line from the powerhouse to a new substation that would interconnect to the Applicant's existing or planned 8.5 miles transmission lines. There are three existing 345 kV transmission lines located within 20 miles. Intransmission addition, there are plans for the alignment of a future 500 kV transmission line (Gateway West) near these corridors. The Exhibit 3 maps illustrate one potential transmission line routing and the potential locations of an above-ground switchyard near the generating/pumping units.

1.4 Average Annual Energy Production and Installed Capacity

The purpose of this Project would be to provide energy storage, support, and balance to PacifiCorp's system while allowing for the incorporation of additional variable renewable generation resources such as wind and solar. The Project would pump water from the lower reservoir during times when surplus energy from other resources is available and generate electricity during periods of high demand. Based on customer energy demands and available energy production on PacifiCorp's system, the Project could pump and generate multiple times in a 24-hour period.

The total estimated annual energy production is 5.4 terawatt-hours (TWh). The installed capacity of the Project would be 1,800 MW. The gross hydraulic head as proposed is 1,490 feet and the typical daily output (based on a daily fill-and-run cycle with 8 hours of generation) would be 14,400 megawatt-hours (MWh). The Project would have an anticipated 80 percent round-trip efficiency rating so daily pumping energy required (based on a daily fill-and-run cycle) would be 18,000 MWh.

Six 300-megawatt (MW) generating/pumping units are proposed. It is anticipated the turbines could be impulse or reaction type.

1.5 Lands of the United States

The proposed preliminary permit boundary encompasses approximately 11,605 acres of lands of the United States. Of these lands of the United States, 1,948 acres are managed by the Bureau of Land Management and 9,657 acres by the USFWS.

1.5.1 U.S. Bureau of Land Management

The upper reservoir, penstocks, powerhouse/pumping station, access roads, switchyard, and a portion of the transmission line are proposed on lands of the United States managed by the U.S. Department of Interior, Bureau of Land Management. These lands are depicted on the Application for Preliminary Permit ("Application") boundary maps in Exhibit 3 – Sheets 1, 2 & 3, Appendix A – FERC Form 587 and in Appendix B – Listing of Lands of the United States. As required in 18 CFR 4.81, the Applicant has sent these forms to the Bureau of Land Management state office in Boise, Idaho.

1.5.2 U.S. Fish and Wildlife Service

The lower reservoir is proposed on lands of the United States managed by the USFWS as part of the Bear Lake National Wildlife Refuge. These lands are depicted on the Application boundary maps in Exhibit 3 – Sheets 1, 2 & 3, Appendix A – FERC Form 587 and in Appendix B – Listing of Lands of the United States. The Applicant currently actively utilizes refuge lands (the Mud Lake Regulation Reservoir), through a 1907 federal right-of-way, for the storage and release of diverted Bear River water. In concert with this Application submittal, the Applicant has sent these forms to the USFWS state office in Boise, Idaho.

1.5.3 National Wild and Scenic Rivers System

There are no known areas within or in the vicinity of the proposed project boundary that are included in or have been designated for study for inclusion in the National Wild and Scenic Rivers System.

1.5.4 Wilderness Act

There are no known areas within the proposed project boundary that, under the provisions of the Wilderness Act, have been designated as a wilderness area, recommended for designation as a wilderness area, or designated as a wilderness study area.

1.6 Public Interest

As a rate-regulated electric utility, PacifiCorp serves its customers under a cost-of-service model that delivers energy solutions to customers at prices that are below national and regional averages. PacifiCorp is the largest grid operator in the western United States and serves the energy needs of 2 million customers across six western states through owned and contracted energy resources. PacifiCorp shares a vision with its customers and communities in which clean energy from across the West powers jobs and innovation. Over the past several years, PacifiCorp has outlined an ambitious path to substantially increase its renewable energy capacity, evolving its existing portfolio and connecting supply with demand through an expanded, modernized transmission system.

The proposed Project would support the public interest by advancing PacifiCorp's capability to serve customers with clean, affordable and reliable energy service using renewable energy storage and carbon-free generation of electricity. Storage resources such as the proposed Project will be increasingly necessary to balance the rising percentage of variable wind and solar energy on PacifiCorp's system with dynamic customer energy needs.

In addition to the ability of the Project to support progress towards a clean energy future, the proposed Project would create job opportunities during construction and long-term operations and maintenance positions. The investments in the project would also support the local community through an expanded tax base along with sales and use taxes resulting from construction.

The Applicant's Project proposes to use as its lower reservoir an area already used to store water. This eliminates the need to inundate new lands for the lower reservoir and creates increased water storage capacity. The additional storage capacity created by the proposed Project is the amount of water surcharged in the lower reservoir, that is, the amount of water stored above the normal elevation of the Mud Lake Regulation Reservoir. It is anticipated the additional storage will amount to approximately 16,000-acre feet of water that will be available for irrigation and power generation purposes.

The Applicant recognizes that creation of a new lower reservoir within Mud Lake Regulation Reservoir would impact wetlands within the Bear Lake National Wildlife Refuge. The Applicant has proposed a wetland study in this Application to identify wetlands in the proposed lower reservoir area and evaluate the potential to provide mitigation for these impacts on the Applicant's nearby properties. In addition, the study will look at benefits of implementing components of the Bear Lake National Wildlife Refuge and Oxford Slough Waterfowl Production Area Comprehensive Conservation Plan (USFWS 2013).

As with most FERC-licensed hydropower projects, the proposed Project seeks to provide additional public recreation and environmental protection and enhancement benefits, all supporting the public interest of the Project.

EXHIBIT 2 - DESCRIPTION OF STUDIES

2.1 Study Process

Prior to submittal of this Application, the Applicant reviewed existing data sources (see Section 2.6 References for data sources), conducted field visits, and performed conceptual engineering analyses. The Applicant proposes to conduct the studies listed below to further evaluate the technical, economic, financial, and environmental feasibility of the proposed Project in support of an application for license.

These studies and analyses will provide critical inputs to the decision process to proceed with a Notice of Intent and a Preliminary Application Document in the pursuit of a FERC project license.

The implementation of studies will be conducted in accordance with applicable federal and state permitting requirements. Any necessary permits or landowner permissions needed will be obtained in order to conduct the studies described here.

The Applicant's professional staff, along with qualified third-party consultants, will complete the preliminary studies described below. Applicant staff and consultant support may include civil, mechanical, electrical, and geotechnical engineers; cultural resource and recreation professionals; biologists; visual resource professionals; hydrologists; and water quality professionals.

2.1.1 Cultural Resource Study

A literature search for existing site information in the Idaho State Historic Preservation Office database will be performed. Should any documents be identified in the literature search they will be reviewed to identify known cultural resources in the Project area. Any areas of potential disturbance from implementation of studies will be cleared in advance with pedestrian survey methods. Any cultural clearances needed for preliminary studies will be coordinated with the State Historic Preservation Office, Indian tribes, and federal land managers.

2.1.2 Energy Needs and Economic Analysis

An energy needs analysis of the proposed Project's ability to support variable renewable resources and contribute to balancing energy supply and demands will be performed. The analysis will include estimates of power production and renewable power integration. Long-term Project economics will be analyzed that will include cost data from other studies proposed in this document. In addition, the Project may be evaluated in the Applicant's Integrated Resource Plan, which would evaluate the Project's ability to contribute to a least-cost, least-risk resource portfolio.

2.1.3 Engineering Studies

Preliminary engineering designs will be prepared for the powerhouse/pump station, upper and lower intake/outlet structures, upper and lower reservoirs, transmission lines, auxiliary spillway, dam and dikes, and penstock tunnels to determine the feasibility, estimated costs and construction timelines.

2.1.4 Environmental Studies

The following actions will be completed to inform the Project's environmental setting:

Fisheries Studies – A literature review will be performed and an annotated bibliography of existing fisheries studies and data for the Mud Lake Regulation Reservoir will be prepared.

Nesting Birds – A nesting bird survey will be performed in the areas potentially affected by the development of the lower reservoir.

Sensitive Plants – Plant communities will be delineated within areas potentially affected by Project development. In these same areas, surveys will be conducted for sensitive plants listed in state and federal databases.

Terrestrial and Avian Species – Wildlife habitat will be delineated within areas potentially affected by Project development. State and federal databases will be queried to develop a list of threatened, endangered, or sensitive species potentially occurring in the project area.

Water Quality – A literature review will be performed and an annotated bibliography of water quality studies and data sources for the Mud Lake Regulation Reservoir will be prepared.

Information obtained from the environmental studies will be used to prepare the discussion of resources and potential impacts, as well as study plans that could be proposed in a Preliminary Application Document.

2.1.5 Geotechnical Analysis

A geotechnical evaluation will be completed to assess existing geological, seismic, aerial, and soil data. An analysis will be completed of the suitability of area soils and rock for use as construction material and as foundations. Additional borings, soundings, soil sampling, and laboratory testing of materials may be conducted as needed to inform preliminary engineering studies.

2.1.6 Wetland Study

A wetland study will be completed to assess the wetlands in the proposed lower reservoir area and evaluate mitigation potential on the Applicant's nearby properties. In addition, the study will look at the potential mitigation benefits of implementing components of the Bear Lake National Wildlife Refuge and Oxford Slough Waterfowl Production Area Comprehensive Conservation Plan (USFWS 2013). This information will be used in the discussion of resources and potential impacts, as well as study plans that could be proposed in a Preliminary Application Document.

2.1.7 Recreation Study

An assessment of recreation uses in the project area and the potential Project effects on recreation will be prepared. This information will be used in the discussion of resources and potential impacts, as well as study plans that could be proposed in a Preliminary Application Document.

2.1.8 Survey and Topography

A topographic and boundary survey of the proposed project area will be completed. This information will be used to prepare the preliminary engineering plans, a proposed project boundary, and land ownership information.

2.1.9 Transmission Interconnection Study

Consistent with the procedures outlined in Applicant's Open Access Transmission Tariff filed with FERC, transmission interconnection studies will be completed to determine the feasibility of interconnecting the proposed Project and any network upgrades that may be necessary, and their associated cost. The interconnection studies will determine the location, number of circuits, voltage, and configuration of the Project's interconnection with the regional utility network.

2.1.10 Transportation Study

An analysis of the area roadways and their capacity to support construction and operation of the Project will be completed.

2.1.11 Visual Resource Study

A baseline evaluation of existing visual resources at the Project site and from key observation points will be prepared. Visual simulations will be prepared from key observation points that incorporate Project structures including the lower reservoir and dike, upper reservoir and dam, transmission line, switch yard, and Project roads. The visual simulations and baseline conditions will be used to identify preliminary issues or potential accommodations in the preliminary engineering work. This information will be used to prepare the discussion of resources and preliminary issues in a Preliminary Application Document.

2.1.12 Access to Conduct Studies

No new road construction is proposed for the purpose of conducting the studies outlined in this Application. If after further scoping, geotechnical and engineering studies proposed in this Application require additional temporary access routes, those routes and subsequent restoration will be coordinated with the federal land managers and private owners.

2.2 Work Plan for New Dam Construction

The Applicant proposes construction of a roller-compacted concrete dam to form the upper reservoir. As geotechnical and engineering analysis proceeds and the need for additional field investigations is identified, the Applicant will submit investigation work plans to the FERC.

The Applicant proposes construction of a rock-armored levee to form the lower reservoir. As geotechnical and engineering analysis proceeds and the need for additional field investigations is identified, the Applicant will submit investigation work plans to the FERC.

Information about field investigations will be submitted following the guidelines in 18 CFR § 4.81 that require the following:

(i) A description, including the approximate location, of any field study, test, or other activity that may alter or disturb lands or waters in the vicinity of the

proposed project, including floodplains and wetlands; measures that would be taken to minimize any such disturbance; and measures that would be taken to restore the altered or disturbed areas; and

(ii) A proposed schedule (a chart or graph may be used), the total duration of which does not exceed the proposed term of the permit, showing the intervals at which the studies, investigations, tests, and surveys, identified under this paragraph are proposed to be completed.

(iii) For purposes of this paragraph, *new dam construction* means any dam construction the studies for which would require test pits, borings, or other foundation exploration in the field.

2.3 Waiver

The Applicant is not requesting a waiver from the requirement to submit work plans for new dam construction.

2.4 Costs and Financing

2.4.1 Estimated Costs

The estimated costs of carrying out the scope of work described in Exhibit 2 is \$1,855,000 allocated as follows:

Cultural Resources	50k
Energy Needs & Economic Analysis	150k
Engineering (includes field investigations)	\$1,000k
Environmental	\$200k
Geotechnical	\$200k
Wetlands	\$75k
Recreation	\$25k
Survey and Topography	\$75k
Transmission Interconnect	\$25k
Transportation	\$20k
Visual Resources	\$35k
ESTIMATED TOTAL STUDY COSTS	\$1,855k

2.4.2 Financial Sources

The Applicant will self-finance the studies, investigations and consultation activities identified in this Application.

Retail and wholesale electricity revenue, along with energy and direct costs, are the key drivers of the Applicant's financial results of operations. The Applicant's net income for the year ended December 31, 2020, was \$741 million on operating revenues of \$5.3 billion. The Applicant's operating revenue increased \$273 million for 2020 compared to 2019 due to higher retail revenue of \$250 million and higher wholesale and other revenue of \$23 million. For the same period, net

income decreased by \$32 million for 2020 compared to 2019, primarily due to increased operation and maintenance expenses.

The Applicant's revenues are sufficient to meet the costs identified in this Application. Additional financial data is presented in Berkshire Hathaway Energy Company's December 31, 2020, annual Form 10-K report available at:

https://www.brkenergy.com/assets/upload/financial-filing/20201231_BHE%20Form%2010-K.pdf.

2.5 Schedule for Studies

The schedule for completion of the studies outlined in this Application is presented in the table below. It is the Applicant's intent that these studies be completed along this timeline. This schedule assumes that a preliminary permit will be issued by December 1, 2021.

Preliminary Permit Issued	December 2021
Group A studies to be initiated first – Energy Needs & Economics, Engineering, Geotechnical, Wetlands, and Survey and Topography.	January 2022 – April 2024
Group B studies to be initiated second – Cultural Resources, Nesting Birds, Sensitive Plants, Terrestrial and Avian Species, Water Quality, Recreation, Transmission Interconnect, Transportation, and Visual Resources.	
Submit Work Plan for Field Investigations – New Dam Construction	Prior to August 2022
Complete Initial Environmental and Economic Analyses	October 2024
Initiate the preparation of the NOI and PAD	November 2024
File NOI and PAD	November 2025

2.6 References

- Allen, C. 2012. Assessing Transportation and Capture of Total Suspended Solids (TSS) and Nutrients through the Dingle Marsh Complex.
- Belmont, P., Donovan, M., Brahney, J., Capito, L., and Burger, Z. 2018. Sediment Dynamics in the Bear River-Mud Lake System (Final Project Report). Utah State University, Logan, Utah.
- Coogan, J.C., 1997. Geologic Map of the Bear Lake South Quadrangle, Rich County, Utah. Utah Geological Survey.
- Hecker, S. 1999. Eastern Bear Lake Fault, 2364. Retrieved from Utah Geological Survey: <u>https://geology.utah.gov/docs/geothermal/ngds/Activefaults/2364.pdf</u>.

- McCalpin, J.P. 2003. Neotectonics of Bear Lake Valley, Utah and Idaho; A Preliminary Assessment. Paleoseismology of Utah, Volume 12, Miscellaneous Publication 03-4, Utah Geological Survey.
- Oriel, S.S. and L.B. Platt. 1980. Geologic Map of the Preston 1°X2° Quadrangle, Southeastern Idaho and Western Wyoming. United States Geological Survey. Miscellaneous Investigations Series. Map I-1127.
- Reheis, M.C., B.J. Laabs, and D.S. Kaufman. 2009. Geology and Geomorphology of Bear Lake Valley and Upper Bear River, Utah and Idaho. The Geologic Society of America.
- Rennels, D.C. and H.M. Hudson. 2012. Pipe Flow, A Practical and Comprehensive Guide. New Jersey: John Wiley & Sons.
- Tullis, J.P. 1989. Hydraulics of Pipelines: Pumps, Valves, Cavitation, Transients. John Wiley & Sons.
- U.S. Fish and Wildlife Service. 2013 Bear Lake National Wildlife Refuge and Oxford Slough Waterfowl Production Area Comprehensive Conservation Plan. Available at: <u>https://ecos.fws.gov/ServCat/DownloadFile/165926</u>.
- U.S. Geological Survey (USGS). 2020. U.S. Earthquake Hazards Faults. Retrieved from U.S. Geological Survey Earthquake Hazards Program: Faults (usgs.gov)
- Utah Geospatial Resource Center (UGRC). 2021. 2016 Bear Lake, Bear River, Cache Valley, and Upper Weber Valley LiDar Elevation Data. Utah Automated Geographic Reference Center. <u>http://gis.utah.gov/data/elevation-and-terrain/2016-lidar-blbrcvuwv/</u>. Accessed March 2021.
- Yonkee, W.A. and A.B. Weil. 2011. Evolution of the Wyoming Salient of the Sevier Fold-Thrust Belt, Northern Utah to Western Wyoming. In Sevier Thrust Belt, Northern and Central Utah and Adjacent Areas. Edited by D.A. Sprinkel, W.A. Yonkee, and T.C. Chidsey, Jr. 1-56. Utah Geological Association Publications 40.
- PacifiCorp. 2019. Integrated Resource Plan, October 18, 2019. https://www.pacificorp.com/energy/integrated-resource-plan.html

EXHIBIT 3 - PROJECT MAPS











APPENDIX A – FERC FORM 587

LAND DESCRIPTION

Public Land States (Rectangle Survey System Lands)

1. STATE	IDAHO	2. FERC PR	OJECT NO.	N/A		
3. TOWNSHIP	13S	RANGE	44E	MERIDIAN	BOISE	
4. Che	eck one:			Check one:		
x	License Preliminary Permit			x Pending Issued:		
If preliminary permit	is issued, give expiration date	e: <u>N/A</u>				

5. EXHIBIT SHEET NUMBER OR LETTERS

Section 6	5	4	3	2	1
7	8	9	10	11	12
18	17	16	15	14	13
19	20	21	22	23	24
30	29	28	27	26	25
			PacifiCorp, Exhibit 3, Sheet 2		
31	32	33	34	35	36
			PacifiCorp, Exhibit 3, Sheet 2	PacifiCorp, Exhibit 3, Sheet 2	

6. Contact's name Mark Stenberg

Telephone No. 208 339-9552

LAND DESCRIPTION

Public Land States (Rectangle Survey System Lands)

1. STATE	IDAHO	2. FERC PR	2. FERC PROJECT NO.			
3. TOWNSHIP	_14S	RANGE	44E	MERIDIAN	BOISE	
4. C	heck one:			Check one:		
x	License Preliminary Permit			<u>x</u> Pending Issued:		
If preliminary perm	it is issued, give expiration d	ate: <u>N/A</u>				

5. EXHIBIT SHEET NUMBER OR LETTERS

Section 6	5	4	3	2	1
			PacifiCorp, Exhibit 3, Sheet 2		
7	8	9	10	11	12
			PacifiCorp, Exhibit 3, Sheet 2		PacifiCorp, Exhibit 3, Sheet 2
18	17	16	15	14	13
USFWS/Private, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2	USFWS/State of Idaho, Exhibit 3, Sheet 2	USFWS/PacifiCorp, Exhibit 3, Sheet 2	PacifiCorp, Exhibit 3, Sheet 2	PacifiCorp, Exhibit 3, Sheet 2
19	20	21	22	23	24
	USFWS, Exhibit 3, Sheet 2		USFWS, Exhibit 3, Sheet 2		
30	29	28	27	26	25
	USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3. Sheet 2	USFWS, Exhibit 3, Sheet 2	
31	32	33	34	35	36

6. Contact's name <u>Mark Stenberg</u>

Telephone No. 208 339-9552

Form FERC-587 OMB No. 1902-0145 (Expires 10/31/2021)

LAND DESCRIPTION

Public Land States (Rectangle Survey System Lands)

1. STATE	IDAHO	2. FERC	PROJECT NO.	N/A	
3. TOWNSHIP	_14S	RANGE	45E	MERIDIAN	BOISE
4. Che x					
Section 6	5	4	3	2	1
7	8	9	10	11	12
PacifiCorp,Exhibit 3, Sheet 2	PacifiCorp, Exhibit 3, Sheet 2			Private, Exhibit 3, Sheet 2	
18 PacifiCorp,Exhibit 3, Sheet 2	17 PacifiCorp, Exhibit 3, Sheet 2	16	15 Private, Exhibit 3, Sheet 2	14 BLM/Private, Exhibit 3, Sheet 2	13
19	20	21 Private, Exhibit 3, Sheet 2	22 BLM/Private, Exhibit 3, Sheet 2	23	24
30	29 Private, Exhibit 3, Sheet 2	28 BLM/Private, Exhibit 3, Sheet 2	27	26	25
31	32 BLM/Private, Exhibit 3, Sheet 2	33 BLM/Private, Exhibit 3, Sheet 2	34	35	36

6. Contact's name Mark Stenberg

Telephone No. 208 339-9552

LAND DESCRIPTION

Public Land States (Rectangle Survey System Lands)

1. STATE	IDAHO	2. FERC PROJECT NO.		N/A		
3. TOWNSHIP	158	RANGE	44E	ME		BOISE
4. Che	eck one:			Check one:		
x	License Preliminary Permit			<u> </u>	ending sued:	
If preliminary permit is i	ssued, give expiration date:	N/A				

5. EXHIBIT SHEET NUMBER OR LETTERS

Section 6	5	4	3	2	1
	USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2
7	8	9	10	11	12
		USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2	USFWS, Exhibit 3, Sheet 2	USFWS/BLM, Exhibit 3, Sheet 2
18	17	16	15	14	13
PacifiCorp, Exhibit 3, Sheet 2	PacifiCorp, Exhibit 3, Sheet 2	USFWS/PacifiCorp, Exhibit 3, Sheet 2	USFWS/PacifiCorp, Exhibit 3, Sheet 2	USFWS/PacifiCorp, Exhibit 3, Sheet 2	USFWS/BLM/Private, Exhibit 3, Sheet 2
19	20	21	22	23 USFWS/State of Idaho, Exhibit 3, Sheet 2	24 USFWS/BLM/ PacifiCorp/Private, Exhibit 3, Sheet 2
30	29	28	27	26	25
					Private, Exhibit 3, Sheet 2
31	32	33	34	35	36

6. Contact's name Mark Stenberg

Telephone No. 208 339-9552

LAND DESCRIPTION

Public Land States (Rectangle Survey System Lands)

1. STATE	IDAHO	2. FERC	PROJECT NO.	N/A	
3. TOWNSHIP	15S	RANGE	45E	MERIDIAN	BOISE
4. Che x	ck one: License Preliminary Permit s issued, give expirati	on date:	N/A	Check one: <u>x</u> Pending Issued:	
	5.	EXHIBIT SHEET NU	JMBER OR LETTER	S	
Section 6 Private, Exhibit 3, Sheet 2	5 Private, Exhibit 3, Sheet 2	4	3	2	1
7 BLM/Private, Exhibit 3, Sheet 2	8	9	10	11	12
18 BLM/Private, Exhibit 3, Sheet 2	17 Private, Exhibit 3, Sheet 2	16	15	14	13
19 BLM/Private, Exhibit 3, Sheet 2	20 BLM/Private, Exhibit 3, Sheet 2	21	22	23	24
30 Private, Exhibit 3, Sheet 2	29 BLM, Exhibit 3, Sheet 2	28	27	26	25
31	32	33	34	35	36

6. Contact's name Mark Stenberg

Telephone No. 208 339-9552

APPENDIX $\boldsymbol{B}-\boldsymbol{L}\textsc{isting}$ of Lands of the United States

TOWNSHIP	RANGE	SEC		QQ	GOVTLOTN	GIS_ACRES	Agency
14S	44E		15	SWSE	0	17.87	USFWS
14S	44E		16	SWNW	0	9.20	USFWS
14S	44E		17	NENW	0	3.54	USFWS
14S	44E		17	NENW	5	10.29	USFWS
14S	44E		17	NESW	0	40.48	USFWS
14S	44E		17	NWNE	0	3.70	USFWS
14S	44E		17	NWNW	0	3.35	USFWS
14S	44E		17	NWNW	6	32.90	USFWS
14S	44E		17	SENE	0	40.08	USFWS
14S	44E		17	SENW	0	40.43	USFWS
14S	44E		17	SESW	0	40.54	USFWS
14S	44E		17	SWNE	0	40.45	USFWS
14S	44E		17	SWNW	0	40.33	USEWS
145	44E		17	SWSE	0	40.56	USEWS
145	44F		18	SENE	0	38.21	USEWS
145	44F		18	SWNF	0	14 11	USEWS
145	44C 44F		20	NESE	0	40.07	
145	44C 44F		20		0	40.07	
1/10	44C 44E		20		0	40.07	
145	44L 44E		20		0	40.07	
145	440		20		0	40.07	
145	440		20		0	40.07	
145	440		20		0	40.07	
145	44C		20		0	40.07	
145	44C		22		0	40.41	
145	44C		22		0	40.38	
145	44C		22		0	40.17	
145	44C		22		0	40.31	
145	44E		22	SESW	0	40.04	USEWS
145	44E		22	SWINE	0	40.31	
145	44E		22	SWSE	0	40.04	USEWS
145	44E		26	NENW	0	0.03	USEWS
145	44E		26	NESW	0	9.05	USEWS
145	44E		26	NWNW	0	38.31	USEWS
14S	44E		26	NWSW	0	40.51	USFWS
14S	44E		26	SENW	0	2.65	USEWS
14S	44E		26	SESW	0	32./1	USFWS
14S	44E		26	SWNW	0	40.69	USFWS
14S	44E		26	SWSE	0	0.37	USFWS
14S	44E		26	SWSW	0	40.46	USFWS
14S	44E		27	NENE	0	40.10	USFWS
14S	44E		27	NENW	0	40.07	USFWS
14S	44E		27	NESE	0	40.12	USFWS
14S	44E		27	NESW	0	40.08	USFWS
14S	44E		27	NWNE	0	40.09	USFWS
14S	44E		27	NWSE	0	40.10	USFWS
14S	44E		27	NWSW	0	40.06	USFWS
14S	44E		27	SENE	0	40.11	USFWS

14S	44E	27	SENW	0	40.07	USFWS
14S	44E	27	SESE	0	40.13	USFWS
14S	44E	27	SESW	0	40.09	USFWS
14S	44E	27	SWNE	0	40.09	USFWS
14S	44E	27	SWNW	0	40.06	USFWS
14S	44E	27	SWSE	0	40.11	USFWS
14S	44E	27	SWSW	0	40.07	USFWS
14S	44E	28	NESE	0	40.05	USFWS
14S	44E	28	NWSE	0	40.05	USFWS
14S	44E	28	NWSW	0	40.04	USFWS
14S	44E	28	SESE	0	40.05	USFWS
14S	44E	28	SESW	0	40.04	USFWS
145	44E	28	SWNW	0	40.04	USEWS
145	44F	28	SWSF	0	40.05	USEWS
145	44F	28	SWSW	0	40.04	USEWS
145	44F	29	NENE	0	40.02	USEWS
145	44F	29	NESE	0	40.02	LISEW/S
145	44E 44E	20	SENE	0	40.02	
145	44C 44F	20	SESE	0	40.02	
145	44E 44E	22	NENE	0	20.05	
145	44C 44F	32	NESE	0	39.90	
145	44C 44F	32	NESU/	0	40.00	
1/15	44C 44E	22		0	40.00	
145	44L 44E	22		0	20.00	
145	44L 44E	22		0	10 00	
145	44L 44E	32 33		0	40.00	
143	44L 44E	32 22		0	39.94	
143	44L 44E	32 22		0	20.05	
145	44L 44E	32 33		0	39.93	
145	44E	22 22		0	40.00	
145	44E	22 22		0	40.00	
145	44E	33	NESE	0	40.00	
145	44E	33		0	40.00	
145	44E	33		0	40.00	
145	44E	33		0	40.00	USEVVS
145	44E	33	NWSE	0	40.00	USEWS
145	44E	33	NWSW	0	40.00	USEWS
145	44E	33	SENE	0	40.00	USEWS
145	44E	33	SENW	0	40.00	USEWS
145	44E	33	SESE	0	40.00	USFWS
145	44E	33	SESW	0	40.00	USFWS
145	44E	33	SWNE	0	40.00	USFWS
145	44E	33	SWNW	0	40.00	USFWS
14S	44E	33	SWSE	0	40.00	USFWS
14S	44E	33	SWSW	0	40.00	USFWS
14S	44E	34	NENE	0	39.95	USFWS
14S	44E	34	NENW	0	39.99	USFWS
14S	44E	34	NESE	0	39.94	USFWS
14S	44E	34	NESW	0	39.98	USFWS

14S	44E	34	NWNE	0	39.97	USFWS
14S	44E	34	NWNW	0	40.01	USFWS
14S	44E	34	NWSE	0	39.96	USFWS
14S	44E	34	NWSW	0	39.99	USFWS
14S	44E	34	SENE	0	39.95	USFWS
14S	44E	34	SENW	0	39.98	USFWS
14S	44E	34	SESE	0	39.93	USFWS
14S	44E	34	SESW	0	39.97	USFWS
14S	44E	34	SWNE	0	39.96	USFWS
14S	44E	34	SWNW	0	40.00	USFWS
14S	44E	34	SWSE	0	39.95	USFWS
14S	44E	34	SWSW	0	39.99	USFWS
14S	44E	35	NENE	0	1.75	USFWS
145	44F	35	NFNW	0	40.11	USEWS
145	44F	35	NESE	0	15.56	USEWS
145	44F	35	NESE	3	25 46	USEWS
145	44F	35	NESW	0	40 53	
145	44E	35	NWNF	0	27 40	
145	44E	35		0	<u>27.</u> 40 <u>40</u> 21	
145	44E 44E	35		0	40.21	
145	44E 44E	35		0	40.33	
145	44E 44E	35	SENE	0	12 91	
1/15	44C 44F	35	SENIW/	0	10.11	
145	44L 44E	35	SESE	0	20.44	
145	44L 44E	35	SESE	0	11 07	
145	44L 44E	25	SESIN/	4	10.66	
145	44L 44E	35	SWNE	0	40.00	
145	44L 44E	22		0	40.30	
145	44L 44E	25		0	40.58	
145	44L 44E	22	SWSL SW/SW/	0	40.73	
145	44L 45E	1/		0	20 5/	
145	45L 45E	14 22		0	20.27	
145	45E	22		0	20.00	
145	45E	22		0	20.06	
145	45E	20		0	20.00	
145	45E	28	SWINE	0	39.90	
145	45E	32		0	39.20	
100	44E	1		0	3.08	
155	44E	1		5	27.40	USEVVS
155	44E	T	NVVSVV	0	22.35	USEWS
155	44E	1	NVVSVV CNANNA/	9	19.23	USEWS
155	44E	1	SWNW	0	2.74	USEWS
155	44E	1	SWNW	6	38.40	USEWS
122	44E	1	SVVSVV	U	36.60	USEWS
155	44E	1	SWSW 2	10	5.09	USEWS
155	44E	2		U	30.06	USEWS
155	44E	2	NENW	U	30.71	USFWS
155	44E	2	NESE	U	39.85	USFWS
15S	44E	2	NESW	0	39.90	USFWS

15S	44E	2	NWNE	0	30.34	USFWS
15S	44E	2	NWNW	0	30.83	USFWS
15S	44E	2	NWSE	0	39.85	USFWS
15S	44E	2	NWSW	0	39.80	USFWS
15S	44E	2	SENE	0	39.85	USFWS
15S	44E	2	SENW	0	39.93	USFWS
15S	44E	2	SESE	0	39.85	USFWS
15S	44E	2	SESW	0	39.87	USFWS
15S	44E	2	SWNE	0	39.85	USFWS
15S	44E	2	SWNW	0	39.77	USFWS
15S	44E	2	SWSE	0	39.85	USFWS
155	44E	2	SWSW	0	39.83	USFWS
155	44E	3	NENE	0	31.08	USEWS
155	44F	3	NFNW	0	31.30	USEWS
155	44F	3	NESE	0	39.87	USEWS
155	44F	3	NFSW	0	39.86	USEWS
155	11E 11E	2		0	31.00	
155	44L 44E	2		0	31.10	
155	44L //F	2		0	30.86	
155		с С		0	20.06	
155	440	с С		0	20.00	
155	44L //E	2		0	20.86	
155	440	с С		0	20.00	
155	44C	с С		0	39.07	
155	44C	с С	SEST	0	39.07	
100	44E	3 7	SVVINE	0	39.80	
155	44E	3 2	SWINW	0	39.80	
100	44E	3 7	SVVSE	0	39.87	
155	44E	3	SVVSVV	0	39.87	USEVVS
155	44E	4		0	31.55	USEWS
155	44E	4	NENVV	0	31.82	USEWS
155	44E	4	NESE	0	39.88	USEWS
155	44E	4	NESW	0	39.88	USFWS
155	44E	4	NWNE	0	31.68	USFWS
155	44E	4	NWNW	0	31.94	USFWS
15S	44E	4	NWSE	0	39.88	USFWS
15S	44E	4	NWSW	0	39.88	USFWS
15S	44E	4	SENE	0	39.89	USFWS
15S	44E	4	SENW	0	39.88	USFWS
15S	44E	4	SESE	0	39.88	USFWS
15S	44E	4	SESW	0	39.88	USFWS
15S	44E	4	SWNE	0	39.88	USFWS
15S	44E	4	SWNW	0	39.88	USFWS
15S	44E	4	SWSE	0	39.88	USFWS
15S	44E	4	SWSW	0	39.88	USFWS
15S	44E	5	NENE	0	31.41	USFWS
15S	44E	9	NENE	0	39.88	USFWS
15S	44E	9	NENW	0	39.88	USFWS
15S	44E	9	NESE	0	39.87	USFWS

15S	44E	9	NESW	0	39.87	USFWS
15S	44E	9	NWNE	0	39.88	USFWS
15S	44E	9	NWSE	0	39.87	USFWS
15S	44E	9	SENE	0	39.87	USFWS
15S	44E	9	SENW	0	39.88	USFWS
15S	44E	9	SESE	0	39.87	USFWS
15S	44E	9	SESW	0	39.87	USFWS
15S	44E	9	SWNE	0	39.88	USFWS
15S	44E	9	SWSE	0	39.87	USFWS
15S	44E	10	NENE	0	39.87	USFWS
15S	44E	10	NENW	0	39.87	USFWS
15S	44E	10	NESE	0	39.88	USFWS
15S	44E	10	NESW	0	39.88	USFWS
155	44E	10	NWNE	0	39.87	USEWS
155	44E	10	NWNW	0	39.87	USEWS
155	44F	10	NWSF	0	39.88	USEWS
155	44F	10	NWSW	0	39.88	USEWS
155	44F	10	SENE	0	39.87	USEWS
155	44F	10	SENW	0	39.87	LISEW/S
155	44F	10	SESE	0	39.88	LISEW/S
155	44E	10	SESL/	0	39.88	LISEW/S
155	44E	10	SWNF	0	39.87	LISEW/S
155	44E 44E	10	SWNL	0	39.87	
155	44C 44F	10	SWIN	0	30.88	
155	44E 44E	10		0	39.88	
155	44L 44E	11	NENE	0	39.86	
155	44L 44E	11		0	39.80	
155	44L 44E	11	NESE	0	30.80	
155	44C 44E	11		0	20.90	
155	44L 44E	11		0	20.85	
155	44L 44E	11		0	39.80	
155	44L 44E	11		0	20.80	
155	44L 44E	11		0	20.00	
155	44L 44E	11		0	20.00	
155	44L 44E	11		0	20.00	
155	44E	11		0	20.00	
155	44E	11	SESE	0	39.90	
100	44E	11	SESVV	0	39.90	
155	44E	11	SVVINE	0	39.87	
155	44E	11	SWINW	0	39.87	
155	44E	11	SWSE	0	39.90	USEWS
155	44E	11	SWSW	0	39.90	USEWS
155	44E	12	NESW	0	5.85	USEWS
155	44E	12	NESW	6	33.65	USEWS
155	44E	12	IN VV IN VV	0	29.06	USEWS
155	44E	12	NVV NVV	2	12.57	USEWS
155	44E	12	NWSW	U	41.21	USFWS
155	44E	12	SENW	U	4.99	USFWS
15S	44E	12	SENW	0	0.08	USFWS

15S	44E	12	SENW	0	0.13	USFWS
15S	44E	12	SENW	3	34.36	USFWS
15S	44E	12	SESE	8	16.06	BLM
15S	44E	12	SESW	0	5.83	USFWS
15S	44E	12	SESW	7	33.62	USFWS
15S	44E	12	SWNW	0	36.77	USFWS
15S	44E	12	SWNW	3	0.04	USFWS
15S	44E	12	SWNW	3	4.60	USFWS
15S	44E	12	SWSE	0	36.24	BLM
15S	44E	12	SWSW	0	41.00	USFWS
15S	44E	13	NENE	0	30.55	BLM
15S	44E	13	NENE	1	16.23	BLM
15S	44E	13	NENW	2	37.19	USFWS
15S	44E	13	NESE	0	39.44	BLM
15S	44E	13	NESE	5	16.38	BLM
15S	44E	13	NWNE	0	30.75	BLM
15S	44E	13	NWNW	0	40.72	USFWS
155	44E	13	NWSE	0	1.48	BLM
155	44E	13	NWSW	0	36.96	USFWS
155	44E	13	NWSW	6	3.51	USEWS
155	44E	13	SENE	0	35.79	BLM
155	44E	13	SENE	4	16.31	BLM
155	44E	13	SENW	3	39.12	USEWS
155	44E	13	SESE	0	39.84	BLM
155	44E	13	SWNE	0	25.39	BLM
155	44F	13	SWNW	0	39.50	USEWS
155	44E	13	SWSE	0	9.01	BLM
155	44E	13	SWSW	0	35.62	USFWS
155	44E	14	NENE	0	39.78	USEWS
155	44E	14	NENW	0	39.51	USEWS
155	44E	14	NESE	0	39.75	USFWS
155	44F	14	NFSW	0	30.15	USEWS
155	44E	14	NWNE	0	39.77	USEWS
155	44E	14	NWNW	0	39.76	USEWS
155	44E	14	NWSE	0	36.26	USEWS
155	44E	14	NWSW	0	23.58	USEWS
155	44E	14	SENE	0	39.90	USEWS
155	44F	14	SENW	0	39.12	USEWS
155	44F	14	SESE	0	34 12	USEWS
155	44F	14	SWNF	0	39.90	USEWS
155	44F	14	SWNW	0	39.78	USEWS
155	44F	14	SWSF	0	18.84	USEWS
155	44F	15	NENE	0	39 74	USEWS
155	44F	15	NENW	0	40 00	USFW/S
155	44F	15	NWNF	0	39 7/	USF\W/S
155	44F	15	NWNW	0	39.43	USF\W/S
155	44F	15	SENE	0	22.72	
155	44E 44E	15	SENW/	0	1/1 07	
100	77L	тJ		0	14.97	031 003

15S	44E	15 SWNE	0	31.51 USFWS
15S	44E	15 SWNW	0	22.99 USFWS
15S	44E	16 NENE	0	39.73 USFWS
15S	44E	16 NENW	0	34.61 USFWS
15S	44E	16 NWNE	0	38.51 USFWS
15S	44E	16 SENE	0	17.77 USFWS
15S	44E	16 SWNE	0	15.66 USFWS
15S	44E	23 NENE	0	0.27 USFWS
15S	44E	24 NENE	0	39.73 BLM
15S	44E	24 NWNE	0	22.03 BLM
15S	44E	24 NWNW	0	8.81 USFWS
15S	44E	24 NWSE	0	39.90 BLM
15S	44E	24 SWSE	0	39.78 BLM
15S	45E	7 NESE	0	40.85 BLM
15S	45E	7 NESW	0	41.11 BLM
15S	45E	7 NWNE	0	41.10 BLM
15S	45E	7 NWSE	0	40.77 BLM
15S	45E	7 NWSW	3	40.36 BLM
15S	45E	7 SENE	0	41.03 BLM
15S	45E	7 SENW	0	41.00 BLM
15S	45E	7 SESE	0	40.64 BLM
15S	45E	7 SESW	0	41.05 BLM
15S	45E	7 SWNE	0	40.89 BLM
15S	45E	7 SWNW	2	39.99 BLM
15S	45E	7 SWSE	0	40.56 BLM
15S	45E	7 SWSW	4	40.50 BLM
15S	45E	18 NENE	0	40.60 BLM
15S	45E	18 NENW	0	40.94 BLM
15S	45E	18 NESW	0	40.80 BLM
15S	45E	18 NWNE	0	40.56 BLM
15S	45E	18 NWNW	1	40.57 BLM
15S	45E	18 NWSE	0	41.21 BLM
15S	45E	18 NWSW	3	40.27 BLM
15S	45E	18 SENW	0	40.58 BLM
15S	45E	18 SESW	0	40.44 BLM
15S	45E	18 SWNE	0	40.62 BLM
15S	45E	18 SWNW	2	40.34 BLM
15S	45E	19 NENW	7	38.35 BLM
15S	45E	19 NWNW	8	38.48 BLM
15S	45E	19 NWSW	16	37.92 BLM
15S	45E	19 SWNW	9	37.72 BLM
15S	45E	20 SESE	5	42.19 BLM
15S	45E	20 SWSE	4	42.64 BLM
15S	45E	29 NENE	1	41.82 BLM