


Wildfire Safety Division Inspection Report



California Public
Utilities Commission

WILDFIRE SAFETY DIVISION
COMPLIANCE BRANCH

Lead Inspector	MaryBeth Farley	Record ID	MF-PC-001
Inspector Signature	<i>MaryBeth Farley</i>	Inspection Date	November 23, 2020
Utility Rep. Name	Heidi Caswell	Utility ID	PC
Utility Rep. Title	Director-T&D Asset Performance/Wildfire Mitigation	Utility Name	PacifiCorp
Utility Rep. Signature		Utility Address	825 NE Multnomah Street, Suite 2000, Portland, OR 97224
City	Weed	County	Siskiyou
<input type="checkbox"/> SED Notification <input type="checkbox"/> CalFire Notification <input type="checkbox"/> Job Briefing Performed <input type="checkbox"/> Transmission Line <input type="checkbox"/> Distribution Line <input checked="" type="checkbox"/> Substation			
Inspection Notes			
On 11/23/20 I performed an inspection of the outer perimeter of the Weed Substation for safety and vegetation clearances. I also inspected a newly installed recloser. The weather was 34 degrees with 3 mph wind.			
Activity Code	WMP4	WMP6	
Activity Units	1	1	
Accompany Inspector			
Item	Location		HFTD (Tier 1-3)
1	1100-1116 US 97		Tier 2
Activity Code	WMP4 Asset Management and Inspections		
Defect Code			
Defect Code Description			
Equipment Description / ID #			

Asset ID: 32. Substation.	
Latitude	Longitude
41.4312	-122.3892
Description of Location	
Weed Substation	
	
Description of Defects or Comments	
No defects found outside substation.	
Circuit ID	Weed-Weed Junction

Item	Location	HFTD (Tier 1-3)
2	25212-25280 Edgewood Rd	Tier 2
Activity Code	WMP6 Grid Operations and Protocols	
Defect Code		
Defect Code Description		
Equipment Description / ID #		
RC_1661_5G83		
Latitude	Longitude	
41.4474	-122.4312	

Description of Location	
Rural foothill neighborhood	
	
Description of Defects or Comments	
Verified recloser installed.	
Circuit ID	5G83



Item 1:



Vegetation clearances met.



Site secure.



Site secure.



Item 2: Verified recloser installed.

