

OEIS Data Request 2.3

Regarding PPS Customer Minutes of Interruption: In Table 9-1 (page 312) of PacifiCorp’s WMP, “Total Customer Minutes of Interruption” for 2020 and 2021 are blank. Provide the total customer minutes of interruption for 2020 and 2021 or provide an explanation for why these values are unavailable.

Response to OEIS Data Request 2.3

Please refer to the table below, column “Total Customer Minutes of Interruption”. Table 9.1 is from the Company’s 2023 Wildfire Mitigation Plan (WMP), which now contains the Total Customer Minutes of Interruption values.

Table 9-1 PPS Event Statistics

	No. of Events	Total Circuits De-energized	Total Customers Impacted	Total Customer Minutes of Interruption
2020	2	1	2,559 ²³	1,169,463
2021	1	6	1,953	1,113,210
2022	0	0	0	0

²³ As requested in the QDR template from OEIS: customers impacted by PPS: if multiple PPS events impact the same customer, count each event as a separate customer.